



OPEN

Optimization of off-grid hybrid renewable energy systems for cost-effective and reliable power supply in Gaita Selassie Ethiopia

Elsabet Ferede Agajie¹, Takele Ferede Agajie^{1,2}✉, Isaac Amoussou¹, Armand Fopah-Lele³, Wirnkar Basil Nsanyuy¹, Baseem Khan⁴, Mohit Bajaj^{5,6,7}✉, Ievgen Zaitsev^{8,9}✉ & Emmanuel Tanyi¹

This paper explores scenarios for powering rural areas in Gaita Selassie with renewable energy plants, aiming to reduce system costs by optimizing component numbers to meet energy demands. Various scenarios, such as combining solar photovoltaic (PV) with pumped hydro-energy storage (PHES), utilizing wind energy with PHES, and integrating a hybrid system of PV, wind, and PHES, have been evaluated based on diverse criteria, encompassing financial aspects and reliability. To achieve the results, meta-heuristics such as the Multiobjective Gray wolf optimization algorithm (MOGWO) and Multiobjective Grasshopper optimization algorithm (MOGOA) were applied using MATLAB software. Moreover, optimal component sizing has been investigated utilizing real-time assessment data and meteorological data from Gaita Sillassie, Ethiopia. Metaheuristic optimization techniques were employed to pinpoint the most favorable loss of power supply probability (LPSP) with the least cost of energy (COE) and total life cycle cost (TLCC) for the hybrid system, all while meeting operational requirements in various scenarios. The Multi-Objective Grey Wolf Optimization (MOGWO) technique outperformed the Multi-Objective Grasshopper Optimization Algorithm (MOGOA) in optimizing the problem, as suggested by the results. Furthermore, based on MOGWO findings, the hybrid solar PV-Wind-PHES system demonstrated the lowest COE (0.126€/kWh) and TLCC (€6,897,300), along with optimal satisfaction of the village's energy demand and LPSP value. In the PV-Wind-PHSS scenario, the TLCC and COE are 38%, 18%, 2%, and 1.5% lower than those for the Wind-PHS and PV-PHSS scenarios at LPSP 0%, according to MOGWO results. Overall, this research contributes valuable insights into the design and implementation of sustainable energy solutions for remote communities, paving the way for enhanced energy access and environmental sustainability.

Keywords Cost-effective energy solutions, Hybrid energy systems, Optimization algorithms, Renewable energy systems, Rural electrification

¹Department of Electrical and Electronic Engineering, Faculty of Engineering and Technology, University of Buea, PO. Box. 63, Buea, Cameroon. ²Department of Electrical and Computer Engineering, Debre Markos University, Debre Markos, Ethiopia. ³Department of Mechanical Engineering, Faculty of Engineering and Technology, University of Buea, PO. Box. 63, Buea, Cameroon. ⁴Department of Electrical and Computer Engineering, Hawassa University, Hawassa, Ethiopia. ⁵Department of Electrical Engineering, Graphic Era (Deemed to be University), Dehradun 248002, India. ⁶Hourani Center for Applied Scientific Research, Al-Ahliyya Amman University, Amman, Jordan. ⁷Graphic Era Hill University, Dehradun 248002, India. ⁸Department of Theoretical Electrical Engineering and Diagnostics of Electrical Equipment, Institute of Electrodynamics, National Academy of Sciences of Ukraine, Peremogy, 56, Kyiv-57 03680, Ukraine. ⁹Center for Information-Analytical and Technical Support of Nuclear Power Facilities Monitoring of the National Academy of Sciences of Ukraine, Akademika Palladina Avenue, 34-A, Kyiv, Ukraine. ✉email: takele_ferede@dmu.edu.et; mb.czechia@gmail.com; zaitsev@i.ua

Ethiopia, being a populous country in East Africa (with over 100 million people), lies in the tropics between the equator and the tropics of Cancer, stretching from approximately 9.150° North latitude to 40.490° longitude. It is one of the least developed nations with insufficient access to power¹. Approximately 45% of the population has electrical access, whereas 15% of homes have access to power. Urban areas in Ethiopia consume 89.6% of the country's total electricity generation. Approximately 85% of the populace resides in rural regions, where less than 5% have access to power². Despite several stakeholders taking numerous efforts to enhance the energy sector and electricity access, these actions failed to effectively tackle the majority of issues, particularly in rural regions of the country. The country has a significant need for electricity. The purpose of electric power is widely understood and sought after by nearly every segment of the country's population. Aside from lighting, cooking, and mailing, there is a high need for mobile charging, essential for communication technologies. This implies that an increasing amount of energy is needed to support the continuously expanding population.

At this time, a significant proportion of nations rely on traditional energy systems to generate electricity, which results in elevated levels of atmospheric pollution. Petroleum, coal, and fossil fuels are among the most widely utilized energy sources in the mainstream of the ecosphere³. On the contrary, conventional energy sources such as coal, petroleum, and fossil fuels have severe consequences for both the environment and human welfare. To mitigate the issues associated with these traditional energy sources, concerned authorities have implemented numerous measures, while academicians in the field have devoted substantial efforts. Finding clean, dependable, and reasonably priced alternative energy sources is essential given the drawbacks of using fossil fuels for energy uses⁴. Off-grid electricity can be utilized as a substitute for diesel generator power in rural electrification projects provided efficient, dependable, and reasonably priced renewable energy supplies are available. However, adopting any specific system based on renewable energy resources may result in oversizing of components and needless operating and life-cycle expenses due to the intermittent nature of these resources. By integrating one or more renewable energy sources into a hybrid system, these restrictions can be removed. Because the components made of renewable resources complement one another, hybrid systems increase load factors and reduce maintenance and replacement costs⁵. In actuality, energy generation from sporadic energy sources may lead to a misalliance between production and demand. Flexible renewable energy generating systems are paired with energy storage technology to tackle these issues. The storage systems will ensure that the various customers' access to energy is uninterrupted even in the event of a sudden shift in the renewable energy producing systems. Pumped hydro storage systems⁶ are the furthestmost broadly used energy storage technology now in use. They are less expensive and have a longer lifespan than thermal energy storage systems and batteries⁷.

The integration of storage systems into green energy systems for conversion significantly affects energy conversion prices and project budgets. Consequently, achieving the optimal size of these components is a significant challenge. In order to fulfill their objectives efficiently and cost-effectively, Hybrid Renewable Energy Systems (HRES) require well-calibrated component sizes. Numerous optimization approaches have been employed in the scientific literature to accurately scale hybrid renewable energy systems, enabling them to strike a balance between efficiency, cost, and reliability. Include software like HOMER and meta-heuristic methods. Renewable energy systems are often sized using meta-heuristics that consider economic factors like life cycle cost (LCC), COE, NPC, and technical reliability factors such as LOLP, LOLE, and LPSP⁸. Many research initiatives have investigated the appropriate size of off-grid clean energy systems using algorithms known as meta-heuristics that include economic and technical aspects. In reference⁹, the author suggested using HOMER software for optimal sizing simulations and conducting techno-economic evaluations. This study tested various scenarios in order to identify the optimal autonomous system design that involves minimizing the net present cost (NPC) and cost of energy (COE) while staying within substantial constraints. A study that used HOMER software to include pumped hydro storage technology into a PV/Wind/PHES stand-alone system in order to tackle the unpredictable nature of energy from renewable sources was recently published¹⁰. According to the research, the PHES-based renewable energy system is the ideal way for remote communities to achieve total energy self-sufficiency. The HOMER model, which assesses a hybrid solar PV/wind/DG/battery system's potential for supplying energy to a remote rural community in Ethiopia, was described in depth by the researchers in reference¹¹. According to the results of the simulation, the hybrid choice is the best and most financially advantageous one when considering both the Net Present Cost (NPC) and the Cost of Energy (COE).

Harmony search (HS) is a unique optimization technique that Refs.^{12,13} presented in their research to optimize the scaling of a solar/wind power system with a storage component. The enhanced hybrid system based on a weighting factor (IHS-W) exhibits more encouraging outcomes as compared to current approaches for developing trustworthy and economical hybrid systems. Improved fast algorithms are developed to improve search effectiveness and optimization. A hybrid PV-wind producing system, together with biomass and storage, is optimized using a swarm-based artificial bee colony (ABC) approach in¹⁴ outlines the metaheuristics in order to satisfy the electrical load need of a limited region. The researchers validate the effectiveness of the suggested approach on optimal sizing of HRES; the results are compared to those produced using the standard software tool, HOMER, and the particle swarm optimization (PSO) algorithm. Their optimization study demonstrated that the suggested technique provides a superior solution compared to PSO and HOMER. The ideal capacity of a PV-Wind system with batteries was determined using the Improved Hybrid Optimization Genetic Algorithm (IHOGA) as described in Ref.¹⁵. Based on the simulation outcomes, it was determined that the solar-wind system with a battery and converter was a highly viable and economical option for the proposed site. An alternate approach to generating electricity from a combination of solar and wind renewable energy sources in a rural Ethiopian hamlet involves utilizing the GWO technology as described in Ref.¹⁶. This study suggests using the GWO approach to reduce the overall yearly cost of hybrid wind and solar renewable energy systems. The findings suggest that the proposed method effectively ascertains the optimal choice for sizing the hybrid system in terms of a shorter annual total cost and a quicker convergence rate. In order to ascertain the feasibility, the outcomes of the PSO iteration method were juxtaposed with the GWO conclusions. The exceptional performance of the GWO

algorithm has been seen here. From the above, most of the researchers concentrated on electrifying rural areas using PV-Wind hybrid with battery bank, fuel cell and diesel generator as backup system in general. Therefore, research there is limited research on hybrid solar wind in pumped hydro energy storage system. Furthermore, the aforementioned techniques optimize hybrid renewable energy systems by taking into account their unique fitness functions and restrictions, either by using a deterministic approach or by applying HOMER software. The utilization of pumped hydro storage (PHS) is suggested as an alternative to the prevalent batteries found in freestanding hybrid solar-wind systems. These batteries are deemed ecologically detrimental due to their high lead content and sulfuric acid composition. The researchers did not take the cost progression of alternative storage technologies into consideration. The finest and most popular optimization methodology among all of them is GWO, which achieves optimal problem size with high convergence, analysis and evaluation, conceptual simplicity, flexibility, robustness, ease of implementation, and good results when applied to a variety of real-world issues. It is relatively straightforward to tackle multiobjective optimization functions—encompassing parameters such as reliability and carbon emissions, financial aspects, as well as a combination of financial reliability and carbon emissions—utilizing both Gravitational Wave Optimization (GWO) and Gravitational Optimization Algorithm (GOA). The comparison between GWO and other renowned optimization methodologies typically demonstrates a higher degree of efficiency and efficacy with the GWO approach. In summary, both GWO and GOA present viable solutions for multiobjective optimization problems with two or three objective functions.

Ethiopia possesses an abundance of small-scale wind, solar, and hydropower resources that are suitable for electrifying rural areas^{17,18}. It is plausible that a hybrid energy system, by virtue of its enhanced dependability, provides superior energy service in comparison to any individual stand-alone supply system (e.g., solar, wind)¹⁹.

Two distinct optimization methodologies were deployed to tackle a multi-objective optimization conundrum, aiming to minimize both the total life cycle cost and energy cost across diverse components within the renewable energy sources (RES), as well as the Load Point Sampling Probability (LPSP). The comparison of findings garnered from the Gravitational Wave Optimization (GWO) and Gravitational Optimization Algorithm (GOA) was undertaken to discern the most favorable approach. In order to determine which of the three options—Photovoltaic-Pumped Hydro Storage (PV-PHS), Wind-Pumped Hydro Storage (Wind-PHS), and Photovoltaic-Wind-Pumped Hydro Storage (PV-Wind-PHS)—was the most effective, extensive research assessments were carried out, making sure that the load specifications of the chosen location were satisfied.

The research problem at question is how to fulfill the energy needs of rural communities like Gaita Selassie in a cost-effective and reliable manner, while taking into account the constraints and challenges associated with existing energy sources. Previous research has demonstrated the inadequacy and unpredictability of centralized energy systems in remote areas, leading the investigation of alternate options based on renewable energy sources. However, there is a lack of extensive assessments of hybrid renewable energy systems that are customized precisely to the unique needs and limits of rural towns like Gaita Selassie. As a result, the purpose of this research is to address gaps in the literature by developing a novel strategy to building and deploying hybrid renewable energy systems that minimize costs while maintaining reliable energy supply. By combining ideas from the literature study with real-world data and constraints, our problem formulation lays the foundation for offering novel solutions to rural communities' energy challenges.

This study makes a contribution by using a holistic approach to solving the issues of rural electrification and sustainable energy planning in Gaita Selassie and similar environments. This study improves our understanding of the complex processes that influence the adoption and deployment of hybrid renewable energy systems in underprivileged communities by conducting a thorough analysis of existing literature and empirical data. This study greatly enhances the issue by including socio-economic, environmental, and technological factors into the development and improvement of renewable energy solutions specifically designed for rural areas. By clarifying the complex relationships between these elements, it offers vital understanding for policymakers, practitioners, and researchers working towards promoting sustainable energy transitions at the local level. Moreover, the application of innovative metaheuristic optimization techniques, such as the Multiobjective Gray Wolf Optimization Algorithm (MOGWO) and Multiobjective Grasshopper Optimization Algorithm (MOGOA), represents a notable methodological contribution. Through empirical validation and comparative analysis, this research demonstrates the effectiveness of these algorithms in enhancing the performance and cost-efficiency of hybrid renewable energy systems.

Overall, by systematically evaluating and comparing various scenarios for energy provision in Gaita Selassie, encompassing different combinations of solar photovoltaic (PV), wind energy, and pumped hydro-energy storage systems (PHES), this study offers actionable insights for decision-makers seeking to promote sustainable development and energy access in rural communities.

Presentation of the study area

As mentioned in the introduction, Dangila is situated within the Awi Zone of the Amhara regional state in Ethiopia. It is a highland area characterized by moderate temperatures and rainfall. Agriculture serves as the primary source of income for the local community. Gaita Selassie, a rural village within the Dangila district, is located approximately 35 km northwest of the Dangila district. Its geographical coordinates are Latitude 11.12° North and Longitude 37.0° East, with an elevation of 2137 m above sea level. Figure 1 displays the location of Gaita Selassie within the Amhara region of Ethiopia.

Methodology

This study's main goal is to maximize the use of renewable energy (RE) resources, with an emphasis on lowering energy prices and maintaining a steady supply of electricity. To achieve this goal, we conducted a comprehensive analysis of the technical and economic feasibility of various energy sources under different scenarios. This




Figure 1. A map displaying the research area's location.

analysis was carried out using advanced optimization techniques, namely the Grey Wolf Optimization (GWO) and the Grasshopper Optimization Algorithm (GOA). General methodology of the proposed hybrid system is shown in Fig. 2.

Load assessment

A case study was undertaken in the study area focusing on a remote village in Gaita Selassie, located in the Amhara region. The coordinates are 11.12° N latitude and 37.0° E longitude. An off-grid HRES case study was developed to fulfill the community's electricity requirements. Figure 3 depicts the community's load profile on a typical undesirable day. The linked load profile is slightly increased from 6:00–7:00 (1501.57 KW) and 19:00–20:00 (1407.292 KW), while the maximum load demand is connected during this period. In the morning period that is (from 05:00–06:00 to 20:00–21:00 h), the load varies from 137.15 to 406.58 KW. Electricity demand declines to 111.15 KW between 23:00 and 0:00 h.

Resource assessment

Solar resource

The investigation centered around renewable energy resources (RER) including solar, wind, and water resources. The study area experiences consistent solar radiation throughout the year, albeit with slight variations in the duration of daylight between summer and winter months. For instance, summer days tend to be longer while winter days are comparatively shorter. The highest temperature recorded at the selected location was 25.5 °C in February, whereas the lowest temperature, 19.54 °C, occurred in August.

Solar radiation data was acquired from the SODA research data centers for the chosen location. The annual average sun radiation in the study area was calculated to be 6.1 kWh/m²/day, with an average clearness and index score of 0.626. On a monthly basis, solar radiation varied from a minimum of 5.150 to a maximum of 7.00 kWh/m²/day. The Fig. 4 highlight the substantial solar potential of the studied region throughout the year.

Wind resource

Wind power is increasingly being used to meet the increasing demand for energy, particularly in the production of electricity. Wind energy is a well-established source of clean energy that has been efficiently harnessed in many locations. It has the scientific and economic capability for significant expansion, and its ongoing progress might be crucial in global efforts to decrease emissions of greenhouse gases. It is projected that Ethiopia has a wind energy potential of 10,000 MW. The velocity varies between 6 and 9 m/s. The Ethiopian Electric Power Corporation collected wind power data from four locations: Mekele, Nazareth, Gondar, and Afar, in partnership with




Figure 2. General methodology of the proposed hybrid system.




Figure 3. The community’s electricity consumption pattern for each hour of a certain day.




Figure 4. Daily mean temperature, solar radiation, and clearance index data for the study region as found on the SODA research center website.




Figure 5. Average monthly wind velocity at a height of 10 m (SODA research center website).

GTZ. Thus, a comprehensive wind turbine power generating system is recognized as an alternative energy source in Ethiopia. Average monthly wind velocity at a height of 10 m (SODA research center website) is shown in Fig. 5.

PHS potential (water resource)

Ethiopia is distinguished by its diverse topography, which encompasses a range of elevations from over 4000 m above sea level in the Simien Mountains to below sea level in the Danakil Depression. This varied terrain gives the country a wide range of climates, from the cool highlands to the hot, arid lowlands. Ethiopia’s climate is also influenced by its location near the equator, which means that it experiences relatively consistent temperatures year-round.

In terms of its water resources, Ethiopia is home to several large rivers, including the Blue Nile, which contributes to the Nile River Basin, and the Omo River, which flows into Lake Turkana in neighboring Kenya. These rivers are fed by rainfall and runoff from the country’s highlands, making Ethiopia one of the primary sources of water for the Nile Basin. Additionally, Ethiopia has a number of large lakes, including Lake Tana, the largest lake in the country, and Lake Abaya, the second largest. These lakes provide important habitats for wildlife and serve as a source of water for irrigation and hydroelectric power generation.

Ethiopia's abundant water resources have significant potential for irrigation and hydropower generation. According to the Ethiopian Ministry of Water and Irrigation, the country has the potential to irrigate 3.8 million hectares of land and generate 45,000 megawatts of electricity. The monthly average flow rate in the selected study region is reported to be 90.25 cubic meters per second (m³/s) during the dry season and 595.5 m³/s during the rainy season, which demonstrates the considerable variability in Ethiopia's water resources throughout the year.

Given its vast water resources and potential for hydropower generation, Ethiopia has great potential for the widespread adoption of Pumped Hydro Storage (PHS) systems. For these systems to work, there must be an abundance of water resources and high enough places with enough potential energy to pump water from a lower reservoir to a higher one when there isn't much demand for power, and then release it to create energy when there is. PHS systems may deal with the problems of intermittent and variable solar and wind power output by providing an affordable means of managing and storing renewable energy supplies.

Proposed schematic diagram

Pumped Hydro Storage (PHSS), wind, and solar PV are all included in the design of the Hybrid Renewable Energy System (HRES). Figure 6 shows a graphic depiction of the suggested design for this hybrid renewable energy system. Examining the mathematical and economic models that support both the two storage systems and all renewable energy production sources is crucial to determining the ideal size for each component. This thorough comprehension is essential for the precise and effective dimensioning of every system component.

Figure 6 visually portrays that the hybrid system functions autonomously, operating independently from the primary power grid. The primary requirement for energy is met by renewable energy sources, specifically Photovoltaic (PV) panels and wind turbines. These sources work in tandem to fulfill the energy demands without relying on the primary power grid. The operational process of the system is outlined as follows:

- When the output from renewable energy generation sources exceeds the current load demand, and no additional energy supplementation is needed, any surplus energy is redirected to operate the motor pump set. This set-up is responsible for raising water from the lower reservoir to the upper reservoir within the pumped hydroelectric storage (PHES) system. This method ensures that excess renewable energy is efficiently stored for later use, optimizing the system's overall efficiency.
- When the renewable energy sources are insufficient to fulfill the load demand, the turbine generator is activated to generate additional power. This is achieved by utilizing water from the upper reservoir to power the turbine, which in turn generates the required electricity to meet the demand. Simultaneously, water is pumped from the lower reservoir (such as the Quashini River) back to the upper reservoir to ensure the system maintains an energy balance and is operational, even when the renewable energy sources are not able to provide the necessary power.




Figure 6. A diagram illustrating the proposed off-grid solar photovoltaic/wind/pumped hydro energy storage system.

Mathematical modeling of RES

A comprehensive understanding of the mathematical and economic models associated with renewable energy storage and generation systems is crucial in order to accurately determine the size of each component of the system. This level of understanding is integral as it enables a meticulous calibration of each element, thus ensuring optimal operation within the entire renewable energy system. By accurately sizing each component, the system's overall efficiency and effectiveness can be vastly improved. This ensures a more comprehensive utilization of the available resources while effectively addressing the demands of the energy grid or system in question.

Solar photovoltaic generation system

Solar radiation is an abundant and affordable renewable energy source, making it ideal for rural areas. PV module performance is often modeled based on maximum power output behaviors. Factors affecting power output include solar radiation, sun direction, module specifications, and room temperature.²⁰ The energy output of a solar panel is influenced by its surface area, the amount of sunlight it receives, the surrounding temperature, and its efficiency²¹. The model integrates irradiance and temperature data at hourly intervals. The information is shown below:

$$P_{PV}(t) = A \times G(t) \times \eta_{pv} \quad (1)$$

A denotes the surface area of the solar panel, $G(t)$ is the site's hourly irradiance at the location where the array will be installed, and The solar panel's efficiency is denoted by η_{pv} . The efficiency expression is provided in Refs.^{21,22}.

$$\eta_{pv} = \eta_r \times \eta_{pc} \times \left[1 - \beta \left(T_a + \left(\frac{NOCT - 20}{800} \right) \times G(t) - T_{cref} \right) \right] \quad (2)$$

where β : temperature coefficient associated with photovoltaic cells and the photovoltaic module's reference efficiency is denoted by η_r . η_{pc} is a degradation factor that accounts for the modules' operating point, which is optimized with an MPPT converter. In this study, it is set to 1²³; the reference temperature of the solar panel's photovoltaic cells is denoted as T_{cref} , T_a represents the ambient temperature of the site, while NOCT is an exceptional characteristic of the solar panels being used.

Inverter

This study uses unidirectional inverters that convert DC energy into AC energy, directly coupled to the solar panel back. Equation (3) places an important constraint on the overall inverter capacity that must be installed, determined by the total installed power of the PV system.

$$P_{inv} \geq P_{peak-PV} \quad (3)$$

Wind power generation system

With appropriate modeling and management, the wind source stands out as a rich and promising element of HRES. The electric power output from wind turbines (WT) at a specific location is impacted by several factors, including surface topography, hub height, and turbine speed characteristics. The power generated by WT is intrinsically linked to the kinetic energy of the wind. This principle is articulated in Equations^{24,25}, which outline the formulation for the wind field output.

$$P_{WT}(v) = \begin{cases} 0, & v < v_{ci} \\ P_{rated} \times \frac{v - v_{ci}}{v_r - v_{ci}}, & v_{ci} \leq v \leq v_r \\ P_{rated}, & v_r \leq v \leq v_{co} \\ 0, & v > v_{co} \end{cases} \quad (4)$$

where v_{ci} , v_r , and v_{co} represent the turbine's on, rated, and off speeds, respectively. P_{WT} is the power output of WT, and P_{rated} is the rated power of WT. From Eq. (4), the output power of WT is zero below v_{ci} and above v_{co} , and the output power increases linearly with increasing wind speed between v_{ci} and v_r and it generates the rated power between v_r and v_{co} .

The turbine's height from the ground, where the measurement is conducted, has a profound influence on the wind source's power output. Correcting the height to an optimal level is feasible during installation, facilitated by a height adjustment equation. Calculating the wind speed at a fixed height involves considering the wind speed at the reference height and the power law constant, as demonstrated in the subsequent equation²⁶.

$$V = V_{hub} \left(\frac{h}{h_{hub}} \right)^\tau \quad (5)$$

where v is the wind speed calculated at hub height h , V_{hub} is the reference wind speed measured at h_{hub} , and τ is the power law. The power law exponent τ is dependent elevation of the particular site, the temperature, the time of day, the season, and the wind speed.

In this research, the Hellman exponent, denoted as τ , is often assumed to be 1/7 as determined by Eq. (6)²⁷.

$$\tau = \frac{0.37 - 0.088 \ln(v_0)}{1 - 0.088 \ln(z_0/10)} \quad (6)$$

Pumped hydro storage system

Energy balance. The energy balance is the difference between the energy production from the solar P_(PV) and wind P_(WT) fields and the load demand.

$$E_B(t) = E_{PV} + E_{WT} - E_D \quad (7)$$

$$E_B(t) = N_{PV} \times P_{PV}(t) \times \eta_{inv} + P_{WT}(t) \times N_{WT} - P_{load}(t) \quad (8)$$

In addition, the calculation of energy surplus involves a comparison between the additional energy generated and the energy consumed. Pumped Hydro Storage (PHS) activates in the event that renewable energy sources (RES) produce an excess of energy beyond what is needed, provided that the upper reservoir is not already at its maximum capacity. The surplus is computed as the discrepancy between the energy available and the energy consumed by the PHS system in pumping mode, provided that the energy available surpasses the energy consumed by the PHS system in pumping mode. After the upper reservoir is completely filled, the PHS system enters a discharging load state and ceases pumping mode, directing all available energy. Equation (9) succinctly represents the notion of excess energy pertaining to the unloading burden.

$$E_S(t) = E_B(t) - E_P(t) \quad (9)$$

PHSS pumping mode (pump/motor unit). If $E_B(t) > 0$ it means that the output from the PV and wind systems exceeds the load demand. This is an opportune time to employ the pumping mechanism to fill the upper reservoir. The amount of water pumped depends on the water level in the reservoir, available energy, and the maximum power of the PHS in pumping mode.

$$E_P(t) = \min \left\{ \left(\frac{V_{max} - V(t-1)}{3600} \right) \times g \times \rho \times H \times \frac{1}{\eta_P}, \min(P_{Pmax}, E_B(t)) \right\} \quad (10)$$

$$q_{ch}(t) = \frac{\eta_P \times E_P(t)}{g \times \rho \times H} \quad (11)$$

where V_{max} represents the maximum capacity of the reservoir, P_{max} the maximum power of the system in pumping mode; η_P the efficiency of the pumping system; q_{ch} represents the vector expressing the water flow rate when filling the upper reservoir over the course of time. The power $P_P(t)$ consumed when pumping water is defined by²⁸:

$$P_P(t) = \frac{\rho \times g \times q_{ch}(t) \times H}{\eta_P} \quad (12)$$

PHSS generator mode (turbine/generator unit). If $E_B(t) < 0$, it signifies that the demand surpasses the production from the PV and wind system. This necessitates the storage system to supply the necessary energy. The power from the PHS is contingent on factors such as the available water volume in the upper reservoir, the maximum turbine capacity P_{Tmax} , and the energy demanded. If the water volume in the upper reservoir is adequate, it meets the energy requirements of the loads. Otherwise, the storage system provides what it can. This equation represents the operation of the PHS in unloading mode and is adapted from the model presented in the referenced articles²⁸.

$$E_{PHS}(t) = \min \left\{ \left(\frac{V(t-1) - V_{min}}{3600} \right) \times g \times \rho \times \eta_t \times H, \min(P_{Tmax}, |E_B(t)|) \right\} \quad (13)$$

$$q_{dis}(t) = \frac{E_{PHS}(t)}{g \times \rho \times \eta_t \times H} \quad (14)$$

where $V(t-1)$ represents the volume of water available in the water reservoir at time t-1; V_{min} represents the minimum level of water allowed to be maintained in the reservoir that can be used in case of emergency; ρ represents the density of water and is equal to 1000kg/m³; η_t represents the efficiency of the whole generation system, especially the turbines, and generators; g represents the gravitational constant considered here equal to 9.81; q_{dis} represents the rate of water discharge during power generation; H represents the water level in the upper reservoir relative to the lower reservoir; it is the sum of the height of the reservoir relative to the lower reservoir and h_{add} the height induced by the water level in the reservoir is defined by the Eq. (14):

$$h_{add(t)} = \frac{V(t-1)}{area} \quad (15)$$

$$H(t) = h + h_{add(t)} \quad (16)$$

The sort of structure used in the higher tank's design determines the height that is created by the water level there. We may assess it for a particular kind of structure for construction using Eq. (15). This extra height

has been disregarded in this study because to the chosen site's 105-m height in respect to the Quashini River (Ethio-River).

The power P_{PHS} supplied by the PHS system to the loads is determined by the equation²⁹.

$$P_{PHS}(t) = q_{dis} \times g \times \rho \times \eta_t \times H \quad (17)$$

Modeling of upper reservoir (UR)

The amount of water held in the UR plays a vital role in maintaining an uninterrupted power supply to rural areas, especially during extended periods without power. The water level at any given time t in the UR is affected by several factors, including the amount of water pumped in, water utilized for power generation, water volume presents in the reservoir at the preceding time $t - 1$, and water loss due to leakage and evaporation. This equation helps in determining the water level specifically within the UR.

$$V(t) = (1 - \delta) \times V(t - 1) + 3600 \times (q_{ch}(t) - q_{dis}(t)) \quad (18)$$

where δ represents the water loss due to evaporation or leakage as a result of various factors. In addition, the water quantity of the UR is subjected to the following constraint: $V_{min} \leq V(t) \leq V_{max}$.

The total amount of gravitational potential energy stored in the UR, E_C is calculated by the Eq. (19)³⁰:

$$E_C = \frac{\eta_t \times g \times \rho \times V \times H}{3.6 \times 10^6} \quad (19)$$

where E_C is the energy storage capacity of a water reservoir (kWh); V is the volume or storage capacity of the water reservoir (m^3). Therefore, the required volume of the UR can be obtained.

Technical and economical specification of components

The technical and economic characteristics of the components analyzed in this research are fully detailed in Table 1. The costs of the photovoltaic (PV) and wind systems were determined using the 2021 cost data from the International Renewable Energy Agency (IRENA), which was made available in 2022³¹. The expenses associated with building the Pumped Hydro Storage (PHS) system were carefully collected from reference³².

Operational strategies of hybrid system

The functioning of the proposed off-grid solar PV-wind hybrid system, augmented with a pumped hydro energy storage system, in an off-grid setting is presented through the following operational cases.

- In the event that the output from the solar PV and wind turbine sources matches the load power, the solar PV and wind power can be supplied to the fully connected loads.
- If the generated power from the solar PV and wind systems is higher than the load demand, the UR can be filled by the pumping mechanism.
- If the generated power from the solar PV and wind sources is less than the load power, then the PHSS in the generating mode energy storage system is supplied to the connected loads.
- If there is surplus power available in a hybrid renewable energy resource configuration in all cases, then the HRES can send the surplus power to the dumping load.

The functioning of the proposed hybrid system and the energy flow within it are graphically represented in Fig. 7. Detailed descriptions corresponding to each component of the flowchart are provided below it.

Energy management strategies in HRES should be meticulously designed to ensure continuous electricity supply for connected loads, as depicted in Fig. 7. The approach to energy management can be gleaned from the following mathematical formulations: Energy flow scenarios are influenced by the surplus or deficit of energy generated from solar PV and wind sources relative to the electricity demand of connected loads. In such cases, energy flow can be administered according to the flowchart in Fig. 7:

Case 1: When the connected load power and the generated power from solar PV and wind sources are equal, only solar PV and wind power will be able to supply the connected loads.

$$P_{Load}(t) = N_{PV} \times P_{PV}(t) \times \eta_{inv} + P_{WT}(t) \times N_{WT} \quad (20)$$

Case 2: If the generated power from the solar PV and wind systems exceeds the load demand, the upper reservoir (UR) can be replenished using the pumping mechanism. The power sharing for the load is as follows:

$$P_{P-ch}(t) = P_{PV}(t) \times N_{PV} \times \eta_{inv} + P_{WT}(t) \times N_{WT} - P_{load}(t) \quad (21)$$

Case 3: Excess power generated by the solar PV and wind systems can be used to replenish the upper reservoir (UR) through a pumping mechanism when the load requirement is met. The distribution of power for the load is as outlined:

$$P_{PHS-dis}(t) = P_{Load}(t) - [P_{PV}(t) \times N_{PV} \times \eta_{inv} + P_{WT} \times N_{WT}] \quad (22)$$

Case 4: If there is surplus power available in hybrid renewable energy resource configuration in all cases, then the HRES can send the surplus power to the dumping load.

Solar panel	
Model	LUM 24380MP
Max power	380Wp
Length width	1.976 × 0.991m
NOCT	45C
Efficiency	19.41%
Temperature coefficient	0.41%
Capital cost	857 €/kW
O M cost	1%
Life span	25 years
Wind turbine	
Model ³³	GW 150–3.0 MW (PMDD smart wind turbine)
Rated power	500kw
$v_{ci}/v_r/v_{co}$	2.5/10/18m/s
Rotor diameter	150m
Height	100m
Capital cost	1325 €/kW
Operation and maintenance cost	3% of capital cost
Life span	+20years
Inverter ³⁴	
Model	SMA Sunny High-power Peak3 SHP 150–20
DC power	150kW
Efficiency	98%
Initial cost	7548 €
OM cost	1%
Lifetime	Above 20 years
PHS system ³⁵	
Overall efficiency	75%
Cost of power conversion	513 €/kW
Cost of balance	15 €/kW
Cost of reservoir	68 €/kWh
Fixed OM cost	4.6 €/kW
Variable OM	0.22 €/MWh
Economic parameters	
Nominal discount rate (assumed)	7%
Inflation rate	3%
Lifetime of the project	20 years
Algorithm parameters	
Iteration	200
Population number	200

Table 1. Technical and economic parameters of the components.

$$P_{surpls}(t) = P_{PV}(t) \times N_{PV} \times \eta_{inv} + P_{WT}(t) \times N_{WT} - [P_{load}(t) + P_{P-ch}(t)] \quad (23)$$

Evaluation parameters

Reliability of the system

To ensure the high reliability of the new system, the criterion for measuring the energy deficit rate, which is called Loss of Power Supply Probability (LPSP), as used in several other works, is implemented^{65,66}.

Loss of power supply probability (LPSP)

The Loss of Power Supply Probability (LPSP) is an essential determinant in the design of hybrid systems as it measures the degree of difficulty in achieving the specified load levels. Scholars frequently employ this metric to assess the dependability of synthetic renewable energy system sizing obstacles. As used in this work, the LPSP is defined as follows:




Figure 7. An operational flowchart for a proposed off-grid solar PV, wind, and photovoltaic system.

$$LPSP = \frac{\sum_{n=1}^{8760} (P_{load}(t) - P_{PV}(t) \times \eta_{inv} - P_{WT}(t) \times N_{WT} - P_{PHS}(t))}{\sum_{n=1}^{8760} P_{load}(t)} \tag{24}$$

Economic model

The economic factors considered include the energy production cost of the hybrid system and the overall life cycle cost of the system.

Total life cycle cost

System annual investment cost. The total cost of the hybrid renewable energy system was determined using the Net Present Cost (NPC) method. The system’s annual investment cost C_{ann_tot} is calculated as follows:

$$C_{ann_tot} = C_{ann_cap} + C_{ann_rep} + C_{ann_oper} + C_{ann_maint} \tag{25}$$

where C_{ann_cap} , C_{ann_rep} , C_{ann_oper} and C_{ann_maint} are the annual capital cost of system components, the annual cost of system component replacements, the annual operational cost, and the annual cost of maintenance, respectively.

The annual capital cost of hybrid system. To convert the initial investment cost into an annual capital cost, we employ the Capital Recovery Factor (CRF).

$$CRF(r, M) = \frac{r(1+r)^M}{(1+r)^M - 1} \tag{26}$$

r denotes the interest rate (%), and M denotes the project’s period.

The following equations can be used to compute the annual capital cost of various subsystems:

$$\begin{cases} C_{ann_cap_PV} = C_{cap_PV} \times CRF(r, M_{PV}) \\ C_{ann_cap_WT} = C_{cap_WT} \times CRF(r, M_{WT}) \\ C_{ann_cap_PHS} = C_{cap_PHS} \times CRF(r, M_{PHS}) \\ C_{ann_cap_inve} = C_{cap_inve} \times CRF(r, M_{inve}) \end{cases} \quad (27)$$

where C_{cap_PV} , C_{cap_WT} , C_{cap_PHS} , and C_{cap_inve} are the installation costs for the PV system, wind turbine, pumped hydro storage, and inverter, respectively. Whereas PV modules, wind turbines, pumped hydro storage, and inverter lifetimes are represented by M_{PV} , M_{WT} , M_{PHS} , and M_{inve} respectively⁶⁷.

After that, the hybrid system's annual capital investment cost is calculated as follows:

$$C_{ann_cap} = C_{ann_cap_PV} + C_{ann_cap_WT} + C_{ann_cap_PHS} + C_{ann_cap_inve} \quad (28)$$

where $C_{ann_cap_PV}$, $C_{ann_cap_WT}$, $C_{ann_cap_PHS}$, and $C_{ann_cap_inve}$ are the annual percentages of the capital costs of installing the PV system, wind turbine, pumped hydro storage, and inverter, respectively.

The operating and maintenance cost. The major cost of the HRES is the operating and maintenance cost, as there is no fuel cost⁶⁴. It is defined as follows:

$$\begin{aligned} C_{oper\&main} &= C_{oper\&main_PV} \times t_{PV} + C_{oper\&main_WT} \times t_{WT} \\ &+ C_{oper\&main_hydro} \times t_{hydro} + C_{oper\&main_pump} \times t_{pump} \end{aligned} \quad (29)$$

where $C_{oper\&main_PV}$, $C_{oper\&main_WT}$, $C_{oper\&main_hydro}$, and $C_{oper\&main_pump}$ represent the operating and maintenance costs of the wind turbine, turbine-generator unit, and motor-pump set, respectively. On the other hand, the terms t_{PV} , t_{WT} , t_{hydro} , and t_{pump} denote the number of hours of operation during the study period for PV modules, the wind system, the turbine, and the pump, respectively^{62,63}.

The annual replacement cost. The following calculation can be utilized to ascertain the present value of the replacement cost of hybrid system components over the system lifetime³⁶. The detailed computations are demonstrated as follows:

$$C_{rep} = \sum_{j=1}^{n_{rep}} K_{C_rep} C_u \left(\frac{1+i}{1+r} \right)^{\frac{nj}{(n_{rep}+1)}} \quad (30)$$

where i , K_{C_rep} , C_u and n_{rep} are, respectively the replacement inflation rate, system capacity, cost of replaced units, and the number of replacements throughout the project period n . The net present value (NPV) of the system is calculated as follows:

$$NPC = \frac{C_{ann_tot}}{CRF} \quad (31)$$

Cost of energy (COE)

The COE, also known as the cost of generated electrical energy from the hybrid system, is denoted in euros per kilowatt-hour (kWh), and can be calculated utilizing the following equation⁶¹:

$$COE = \frac{C_{ann_tot}}{\sum_{h=1}^{h=8760} P_{load}} = \frac{NPC}{\sum_{h=1}^{h=8760} P_{load}} \times CRF \quad (32)$$

where P_{load} is the value of the hourly load demand.

Problem formulation on optimal sizing of hybrid system

The optimization of hybrid renewable energy systems (HRES) entails selecting the most suitable components and configuring them with the right operational strategy to deliver affordable, effective, dependable, and economically viable alternative energy solutions. Accurately estimating the optimal size of an HRES requires thorough sizing and optimization procedures.

Objective function formulation

For the optimal scaling of the HRES presented in this study, it's crucial to establish an appropriate objective function that incorporates all pertinent variables and parameters, as well as any factors that could directly or indirectly impact the desired outcome. The objective function for this hybrid renewable energy challenge is the sum of the initial capital cost and maintenance cost, which is used to cap the annual COE of the system. This study examined several scenarios to address this optimization problem: those involving only the solar system and PHES; the wind system and PHES; and a hybrid solar-PV and wind system with PHES. This allows for a comparative analysis of the outcomes to determine the optimal configuration. The following outlines the objective functions and constraints that must be satisfied.

$$F_1 = \text{Min}f\{COE\} = \frac{C_{ann_tot}}{\sum_{h=1}^h P_{load}} \quad (33)$$

$$F_2 = \text{Min}f\{LPSP\} = \frac{\sum_{n=1}^{8760} (P_{load}(t) - P_{PV}(t) \times \eta_{inv} - P_{WT}(t) \times N_{WT} - P_{PHS}(t))}{\sum_{n=1}^{8760} P_{load}(t)} \quad (34)$$

Constraints

In an off-grid hybrid renewable energy system (HRES), the components of the power system operate within certain constraints. Optimal operation of the system should be able to maintain a balance in power at all times. The energy production from solar PV, wind turbines, and pumped hydro systems must adhere to upper and lower limits as specified in Eqs. (35), (36), and (37), ensuring the system design constraints are met. The size of the inverter should be equal to or greater than the total power provided by the solar panels, as indicated in Eq. (39). Additionally, the Loss of Power Supply Probability (LPSP) should be less than the predefined reliability index (ε_L) of the system, expressed in Eq. (40), and in this study, ε_L is considered to be less than 1%.

To ensure the proposed new green power plant's reliability, the sizing will be subject to the following constraints:

$$N_{PV}^{\min} \leq N_{PV} \leq N_{PV}^{\max} \quad (35)$$

$$N_{WT}^{\min} \leq N_{WT} \leq N_{WT}^{\max} \quad (36)$$

$$N_{PHS}^{\min} \leq N_{PHS} \leq N_{PHS}^{\max} \quad (37)$$

$$V_{Min} \leq V \leq V_{Max} \quad (38)$$

$$P_{in} \geq P_{peak-PV} \quad (39)$$

$$LPSP \leq \varepsilon_L \quad (40)$$

where, N_{PV}^{\min} , N_{PV}^{\max} , N_{WT}^{\min} , N_{WT}^{\max} , P_{PHS}^{\min} , P_{PHS}^{\max} represent the lower and upper limits of the number of solar panels, the number of wind turbines, the maximum power of PHS, and the capacity of the UR, respectively.

Multiobjective Grey Wolf Optimization (MOGWO) algorithm

The Multiobjective Grey Wolf Optimization (MOGWO) algorithm is an optimization technique based on the social behavior of gray wolves, which is an extension of the Gray Wolf Optimization (GWO) algorithm³⁷. It is intended to handle multiobjective optimization situations in which several competing objectives must be simultaneously optimized^{38,39}. MOGWO can be used to determine the best configurations and control techniques for standalone hybrid renewable energy sources with energy storage systems^{40,41}. These strategies can balance a number of objectives, including maximizing energy efficiency, lowering costs, and limiting environmental effects^{42,43}. To meet the energy needs of a stand-alone system, ascertain the ideal dimensions and arrangement of energy storage components (supercapacitors, batteries), as well as renewable energy sources (wind turbines, solar panels)^{44,45}. Optimize the blend of sustainable energy sources to attain equilibrium among dependability, accessibility, and expenses⁴⁶. Moreover, provides the best energy management and control plans possible for hybrid systems to guarantee effective use of storage and renewable energy sources^{43,47}. Reduce the amount of time you spend switching between different energy sources to make components last longer. The proposed MOGWO code was constructed, as shown in Algorithm 1.

1. Initialization of grey wolf population $X_i (i = 1, 2, 3, \dots, n)$;
2. Initialize a, A and C
3. Calculate the fitness of each search agent
 - Set X_α as the best search agent
 - Set X_β as the second-best search agent
 - Set X_δ as the third-best search agent
4. While ($t <$ maximum number of iterations)
5. For each search agent
6. Update the position of the current search agent by using the equation

$$X_{t+1} = \frac{X_1 + X_2 + X_3}{3}$$
7. End for
8. Update a, A and C
9. Calculate the fitness of all search agents
10. Update X_α , X_β , and X_δ
11. $T = t + 1$
12. End while
13. Return X_α

Algorithm 1. Multiobjective Grey Wolf Optimization (MOGWO)

Multiobjective Grasshopper Optimization Algorithm (MOGOA)

The Multiobjective Grasshopper Optimization Algorithm (MOGOA) is an optimization technique based on the swarming behavior of grasshoppers⁴⁸. It is employed in a variety of domains, including engineering and renewable energy systems, to solve optimization issues^{49,50}. When it comes to energy storage systems and standalone hybrid renewable energy sources, MOGOA can be used to optimize different parts of the system and improve performance^{52,53}. The best sizes for various parts of a hybrid renewable energy system, like solar panels, wind turbines, and energy storage systems, can be found using MOGOA^{51,54}. The optimization process may take into account variables such as energy output, storage capability, and total system expenses^{55,56}. Economic aspects that GOA can take into account include the price of energy production, storage, and system components. It can maximize the hybrid renewable energy system's economic performance while accounting for payback duration and return on investment^{57,58}. The proposed MOGOA code was constructed, as shown in Algorithm 2.

```

1: Initialize the grasshopper population  $X_i (i = 1, 2, \dots, n), c_{\max}, c_{\min}, t_{\max}$  (maximum number of iterations).
2: calculate the fitness function for each search agent.
3: Find the non-dominated PO solutions and initialize external archive (A) with them.
4: While ( $t \leq Max_{iter}$ ) do
5: Update  $c$  using  $c = c_{\max} + t \frac{c_{\max} - c_{\min}}{t_{\max}}$ 
6: For all agents, do
7:   Normalize the distance between grasshoppers.
8:   Update the grasshoppers' position.
9:   calculate the fitness function for each agent.
10:  Find the non-dominated solutions.
11:  update A.
12:  if (A is full) then
13:    Run the grid mechanism to remove one of the current archive members.
14:    Add the new solution to A.
15:  end if
16: end for
17:   $t = t + 1$ 
18: end while
19: Return A (contains PO)

```

Algorithm 2. Multiobjective Grasshopper Optimization (MOGOA)

Results and discussion

Meteorological data

The meteorological data utilized for this study is accessible from reference^{59,60}. The wind speed and solar irradiation data comprise hourly averages over a span of twenty years, commencing from 2000 to 2020, thereby ensuring a robust and reliable dataset. To derive the wind velocity at an altitude of 100 m, Eq. (4) was applied. Figure 8 visually portrays the hourly data pertaining to irradiation, temperature, and wind velocity.

Result presentation on optimal sizing of proposed hybrid system components

This research identified the dimensions of the proposed hybrid system by the quantity of PV modules, wind turbines, and the PHES (energy storage) system's capacity. Evaluation of the optimization algorithms was carried out across 200 iterations and population sizes.

As seen from the simulation result shown in Table 2, the optimal size by using the MOGWO algorithm was obtained in the PV-PHES scenario, the installed capacity PHES is 1.84 MW, the number of solar panels is 13,889, the number of inverters is 36, and the UR volume is 52,529 m³. As for the results obtained using the MOGOA algorithm, the installed capacity PHES is 2.07 MW, the number of solar panels is 10,000, the number of inverters is 26, and the UR volume is 197,000 m³.

The PHES system is used only in the Wind-PHES scenario wherein the wind power supplied is insufficient to meet the energy demand. As results shown in Table 2, the number of WT and the installed capacity for the PHES system obtained by the MOGWO algorithm are 15 and 1.65 MWh, respectively, with the UR volume 45,800 m³. According to the results derived from the MOGOA algorithm, the installed capacity of PHES is 1.67 MW, the number of WT is 18, and the UR volume is 53,200 m³. Notably, the average wind speed reaches its lowest point during the rainy season, spanning from September to October, as depicted in Figs. 5 and 8. Consequently, the PHES storage system plays a crucial role during this season in this scenario.

In the PV-Wind-PHES scenario, the demand for PHES is often minimal because of the existence of the wind system. As indicated in Table 2, the MOGWO algorithm yielded the following results: an installed PHES capacity of 1.52 MW, 5 WT, 2141 solar panels, 6 inverters, and a UR with a capacity of 40,502.1 m³. On the other hand,




Figure 8. Average hourly solar radiation and ambient temperature and wind speed per year.

	Capacity	MOGWO	MOGOA
PV-PHES	Number of solar panels	13,889	14,385
	Number of inverters	36	37
	PHS power (MW)	1.843	2.07
	Upper reservoir volume (m ³)	52,529	197,000
WIND-PHES	Number of wind turbine	15	18
	PHS power (MW)	1.65	1.67
	Upper reservoir volume (m ³)	45,800	53,200
PV-WIND-PHES	Number of solar panels	2141	2215
	Number of wind turbine	5	5
	Number of inverters	6	6
	PHS power (MW)	1.52	1.673
	Upper reservoir volume (m ³)	40,502.1	44,287.5

Table 2. Optimized component capacity utilizing various meta-heuristic optimization techniques.

the MOGOA algorithm returned results with an installed PHES capacity of 1.673 MW, 5 WT, 2215 solar panels, 6 inverters, and a UR with a capacity of 44,287.5 m³.

Economic and reliability parameter analysis of hybrid systems

The outcomes displayed in Fig. 9 and Table 3 present the Pareto front achieved for the multiple scenarios explored. Specifically, the solar-PV-wind-PHES system furnishes an optimal solution with a minimum COE (COE = 0.126 €/KWh) at zero LPSP. This array of comparisons serves to validate the feasibility of the optimal solution yielded by the MOGWO algorithm.

As seen in Fig. 10, MOGWO reached the optimum solution (minimum COE) of 0.126 €/kWh within the predefined operation iterations as well as LPSP values (LPSP = 0%). MOGOA had an optimum energy cost of 0.1906 €/kWh for the objective function and an LPSP value of 0%. It was shown that the MOGWO algorithm was superior to the MOGOA algorithms applied to the hybrid system.

MOGWO optimization algorithm ensures the minimum COE at the proposed location for 2141 solar PV panels, six inverters, five wind turbines, and 1.53 MW capacities of PHES, which has a maximum capacity of UR volume 40,502.1.




Figure 9. Optimal Pareto front set MOGWO.

Evaluation parameters	MOGWO			MOGOA		
	PV-PHES	Wind-PHES	PV-Wind-PHES	PV-PHES	Wind-PHES	PV-Wind-PHES
LPSP (%)	0	0	0	0	0	0
Total cost (€)	7,338,100	15,838,000	6,897,300	7,770,128	18,494,743	7,072,082
Total cost PV (€)	5,394,600	0	835,410	5,587,250	0	864,285
Total cost Wind (€)	0	13,120,000	4,500,900	0	15,744,000	4,500,900
Total cost PHS(€)	1,943,500	2,717,800	1,561,000	2,182,878	2,750,743	1,706,897
COE (€/kWh)	0.1331	0.211	0.1261	0.154	0.382	0.1906

Table 3. Financial parameter evaluation at LPSP = 0 values by using different meta-heuristic optimization.




Figure 10. Convergence rates of MOGWO and MOGOA for the COE and LPSP of the studied system configurations.

Comparison and analysis of optimization techniques on economic and reliability parameter

The findings detailed in Table 4 depict the results attained for the diverse configurations scrutinized. The total costs at zero LPSP for the PV-PHES, Wind-PHES, and PV-Wind-PHES scenarios were €7,338,100, €15,838,000, and €6,897,300 respectively when MOGWO was leveraged. In contrast, the total costs for the same scenarios were €7,770,128, €18,494,743, and €7,072,082 respectively, when the MOGOA algorithm was employed. Additionally,

	PV-PHES	Wind-PHES	PV-Wind-PHES
Capacity of PV(MW)	4.827	0	0.996
Capacity of wind turbine (MW)	0	1.657	2.109
capacity of PHES (MW)	1.84	1.65	1.52
Annual energy generated by solar PV (GWh)	10.158	0	1.565
Annual energy generated by solar wind (GWh)	0	9.138	5.224
Annual energy generated by PHES (GWh)	1.93	0.685	1.095
Annual energy consumed by PHES (GWh)	2.573	0.8589	1.45
Surplus energy (GWh)	5.154	5.939	2.169
Total annual energy generated by PV and wind farm (GWh)	Not applicable	Not applicable	6.79
Total capacity of PV and wind farm (MW)	Not applicable	Not applicable	3.105

Table 4. Summary of MOGWO algorithm results for the optimal solutions.

the COE at zero LPSP obtained with MOGWO for the PV-PHES, Wind-PHES, and PV-Wind-PHES scenarios were €0.1331/kWh, €0.21/kWh, and €0.1261/kWh respectively. As for the results garnered using the MOGOA algorithm, the COE at zero LPSP for the same scenarios were €0.154/kWh, €0.383/kWh, and €0.1906/kWh respectively.

The comparative evaluation of the outcomes generated by the Multi-Objective Gravitational Wave Optimization (MOGWO) and Multi-Objective Gravitational Optimization Algorithm (MOGOA) showcases the superior performance of the MOGWO algorithm, particularly concerning Total Life Cycle Cost (TLCC) and Cost of Energy (COE). As the primary objective of this investigation was to minimize the Total Annualized Cost (TAC) of the system and the COE while guaranteeing the suitable configuration of the components within specified restrictions to meet the energy demands of Gaita Selassie village in the Dangila district, the MOGWO algorithm was deemed the most efficacious solution for this optimization endeavor. As a consequence, the next portions of the research will only include the findings of the MOGWO algorithm.

Comparing the findings derived from the MOGWO algorithm across different scenarios, it is observed that the PV-Wind-PHES scenario boasts a superior position. The TLCC and COE of the PV-Wind-PHES scenario stand at 38% and 18% lower respectively, compared to the Wind-PHSS and PV-PHES scenarios, with LPSP at zero. This underscores the efficacy and efficiency of the PV-Wind-PHES hybrid system in meeting the set objectives.

Figure 11 elucidates the allocation of the overall project cost among the distinct renewable energy sources (RES) in each scenario. Within the Photovoltaic-Pumped Hydro Energy Storage (PV-PHES) scenario, the photovoltaic (PV) system accounts for 73.5% of the total project cost, while the pumped hydro energy storage (PHES) system is allotted the remaining 26.5%.

In the Wind-Pumped Hydro Energy Storage (Wind-PHES) scenario, the wind system consumes a substantial 82.83% of the total project cost, while the PHES system constitutes the remaining 17.15%.

Furthermore, in the PV-Wind-Pumped Hydro Energy Storage (PV-Wind-PHES) scenario, the wind system demands 65.25% of the total project cost, followed by the PV system at 12.11%, and the PHES system at 22.63%.

Evidently, in all scenarios, a significant portion of the total expenses is attributed to the renewable energy systems (RES).




Figure 11. Share of each renewable energy system (RES) in the total project cost.

Application and analysis of optimization techniques on proposed hybrid system

PV-PHES

As presented in Fig. 12, the photovoltaic (PV) field output in the PV-PHES scenario ranges from 0 to 4.827 MW, contributing to an annual energy production of 10.158 GWh. Within this total, 2.573 GWh is utilized by the pumped hydro energy storage (PHES) system to fill the upper reservoir (UR), and 5.1547 GWh represents surplus energy generated over the course of a year. Moreover, the annual energy generated by the PHES system in its generating mode is calculated to be 1.9335 GWh.

Wind-PHES

In the Wind-PHES scenario, the wind farm generates power ranging from 0 kW to 1.657 MW, resulting in an annual energy output of 9.1381 GWh. Among the energy sources considered, the pumped hydro storage (PHS) system employs 859.7 MWh to supply water to the upper reservoir (UR), while the remaining 5.9397 GWh signifies excess energy produced over a span of one year. Notably, the pumped hydro storage (PHS) system pumps a minute portion of the energy generated by the wind system into the UR for the purpose of filling it.

Moreover, the annual energy generated by the PHS system in its generating mode is reported to be 0.6856 GWh.

PV-Wind-PHES

In the PV-Wind-PHES scenario, the wind field output fluctuates between 0 MW and 2.1091 MW, contributing to an annual energy generation of 5.2248 GWh. On the other hand, the solar photovoltaic (PV) farm produces an output varying from 0 to 0.996 MW, resulting in an annual generation of 1.5658 GWh. Cumulatively, when both energy sources are considered, the output ranges from 0 MW to 3.105 MW, with an annual energy generation of 6.7906 GWh. Within this overall output, 1.45 GWh is directed towards filling the upper water tank of the pumped hydro storage system (PHSS), and 2.169 GWh represents surplus energy generated over the course of a year.

Notably, the pumped hydro storage (PHS) system uses some of the energy generated by the wind system to fill the upper reservoir (UR). Furthermore, the PHS system's energy output fluctuates from 0 MW when the PV and wind systems together supply the whole demand to 1.52 MW when their combined output is insufficient to meet the load needs.

In Fig. 13, a comprehensive breakdown of the useful energy proportions is provided for various renewable energy system (RES) configurations. Firstly, within the Photovoltaic-Pumped Hydro Energy Storage (PV-PHES) scenario, approximately half of the total energy generated by the photovoltaic (PV) system is classified as excess energy. Furthermore, about a quarter of the generated energy is directed towards filling the upper tank of the pumped hydro energy storage (PHES) system, while the remainder is directly consumed by the electrical loads.

Second, under the Wind-Pumped Hydro Energy Storage (Wind-PHES) scenario, more than half of the energy produced by the wind system is classified as surplus energy, accounting for around 65% of total energy. Surprisingly, this additional energy exceeds the power needed by the pumped hydro storage system, which accounts for less than 1% of the total energy produced by the wind system.

Finally, in the PV-Wind-PHES scenario, the surplus energy accounts for approximately 31% of the overall energy produced by the wind and PV components combined. It is worth mentioning that the energy employed by the pumped hydro storage system while in pumping mode constitutes an estimated 21% of the total energy generated from renewable sources.

Conclusion and future research directions

In conclusion, this study presents a comprehensive analysis of various scenarios for powering rural areas in Gaita Selassie with renewable energy plants, with a focus on reducing system costs while meeting energy demands. Through the integration of solar PV, wind energy, and pumped hydro-energy storage systems (PHES), we have explored different configurations to optimize the overall system performance. Our findings underscore the significance of metaheuristic optimization techniques, particularly the Multiobjective Gray wolf optimization algorithm (MOGWO), in identifying optimal solutions that minimize both the cost of energy (COE) and total life cycle cost (TLCC) while ensuring reliable energy supply. The hybrid solar PV-wind-PHES system emerges as the most cost-effective solution, demonstrating superior performance in terms of COE and TLCC compared to alternative scenarios. Moreover, our study contributes to addressing the pressing energy needs of rural communities in Ethiopia, aligning with broader efforts to enhance electricity access and promote sustainable development. Moving forward, further research could explore additional factors such as energy storage capacity and grid integration to refine the design and implementation of renewable energy systems in similar contexts.

Expanding on the findings of this study, there are several encouraging paths for future research to further advance our understanding and implementation of hybrid renewable energy systems. Integrating demand response (DR) mechanisms into the hybrid system helps optimize energy production and storage capacity by enabling dynamic load control. Furthermore, exploring sophisticated energy storage management (ESM) technologies, such as enhanced control algorithms and real-time optimization, has the potential to enhance the overall efficiency and dependability of energy storage in hybrid systems. Furthermore, the examination of the incorporation of intelligent grid technologies, including intelligent meters, distribution management systems (DMS), and modern communication networks, can enable immediate monitoring and regulation, hence improving the system's capacity to withstand and adjust to varying conditions. Finally, undertaking extensive environmental impact studies, such as life-cycle assessments (LCAs) and biodiversity assessments, can help give a full knowledge of the hybrid system's environmental sustainability and consequences for local ecosystems. These research directions aim to improve the design, operation, and environmental sustainability of hybrid renewable energy systems, hence promoting sustainable development in off-grid and remote places.




Figure 12. (a–c) MOGWO algorithm results for the optimal solutions.




Figure 12. (continued)




Figure 13. The proportion of total energy produced by the RES between demand, PHS system use, and energy excess.

Data availability

The datasets used and/or analysed during the current study available from the corresponding author on reasonable request.

Received: 25 February 2024; Accepted: 9 May 2024

Published online: 13 May 2024

References

1. Kharrich, M., Hassan, M. H., Kamel, S. & Kim, J. Designing an optimal hybrid microgrid system using a leader artificial rabbits optimization algorithm for domestic load in Guelmim city, Morocco. *Renew. Energy* **223**, 120011 (2024).
2. Kharrich, M., Selim, A., Kamel, S. & Kim, J. An effective design of hybrid renewable energy system using an improved Archimedes Optimization Algorithm: A case study of Farafra, Egypt. *Energy Convers. Manage.* **283**, 116907 (2023).
3. Kharrich, M. *et al.* Optimization based on movable damped wave algorithm for design of photovoltaic/wind/diesel/biomass/battery hybrid energy systems. *Energy Rep.* **8**, 11478–11491 (2022).
4. Kharrich, M., Abualigah, L., Kamel, S., AbdEl-Sattar, H. & Tostado-Véliz, M. An Improved Arithmetic Optimization Algorithm for design of a microgrid with energy storage system: Case study of El Kharga Oasis, Egypt. *J. Energy Storage* **51**, 104343 (2022).
5. Houssein, E. H., Ibrahim, I. E., Kharrich, M. & Kamel, S. An improved marine predators algorithm for the optimal design of hybrid renewable energy systems. *Eng. Appl. Artif. Intell.* **110**, 104722 (2022).
6. Kharrich, M., Mohammed, O. H., Alshammari, N. & Akherraz, M. Multi-objective optimization and the effect of the economic factors on the design of the microgrid hybrid system. *Sustain. Cities Soc.* **65**, 102646 (2021).
7. Hu, J., Zou, Y. & Soltanov, N. A multilevel optimization approach for daily scheduling of combined heat and power units with integrated electrical and thermal storage. *Expert Syst. Appl.* **123**, 729. <https://doi.org/10.1016/j.eswa.2024.123729> (2024).
8. Duan, Y., Zhao, Y. & Hu, J. An initialization-free distributed algorithm for dynamic economic dispatch problems in microgrid: Modeling, optimization and analysis. *Sustain. Energy Grids Netw.* **34**, 101004. <https://doi.org/10.1016/j.segan.2023.101004> (2023).
9. Urf Manoo, M., Shaikh, F., Kumar, L. & Arici, M. Comparative techno-economic analysis of various stand-alone and grid connected (solar/wind/fuel cell) renewable energy systems. *Int. J. Hydrogen Energy* **52**, 397–414. <https://doi.org/10.1016/j.ijhydene.2023.05.258> (2023).
10. Gebrehiwot, K., Mondal, M. A. H., Ringler, C. & Gebremeskel, A. G. Optimization and cost-benefit assessment of hybrid power systems for off-grid rural electrification in Ethiopia. *Energy* **177**, 234–246 (2019).
11. Zhang, W., Maleki, A. & Alhuyi Nazari, M. Optimal operation of a hydrogen station using multi-source renewable energy (solar/wind) by a new approach. *J. Energy Storage* **53**, 104983. <https://doi.org/10.1016/j.est.2022.104983> (2022).
12. Sinha, S. & Chandel, S. S. Review of recent trends in optimization techniques for solar photovoltaic–wind based hybrid energy systems. *Renew. Sustain. Energy Rev.* **50**, 755–769 (2015).
13. Zhang, W., Maleki, A., Rosen, M. A. & Liu, J. Sizing a stand-alone solar-wind-hydrogen energy system using weather forecasting and a hybrid search optimization algorithm. *Energy convers. Manag.* **180**, 609–621 (2019).
14. Hou, R., Maleki, A. & Li, P. Design optimization and optimal power management of standalone solar-hydrogen system using a new metaheuristic algorithm. *J. Energy Storage* **55**, 105521 (2022).
15. Fulzele, J. B. & Daigavane, M. B. Design and optimization of hybrid PV-wind renewable energy system. *Mater. Today Proc.* **5**(1), 810–818 (2018).
16. Geleta, D. K., Manshahia, M. S., Vasant, P. & Banik, A. Grey wolf optimizer for optimal sizing of hybrid wind and solar renewable energy system. *Comput. Intell.* **38**(3), 1133–1162 (2022).
17. Zegeye, A. D. Wind resource assessment and wind farm modeling in Mossobo-Harena area, North Ethiopia. *Wind Eng.* **45**(3), 648–666. <https://doi.org/10.1177/0309524X20925409> (2021).
18. Bayu, E. S., Khan, B., Hagos, I. G., Mahela, O. P. & Guerrero, J. M. Feasibility analysis and development of stand-alone hybrid power generation system for remote areas: A case study of Ethiopian rural area. *Wind* **2**(1), 68–86 (2022).
19. Tofu, D. A., Wolka, K. & Woldeamanuel, T. The impact of alternative energy technology investment on environment and food security in northern Ethiopia. *Sci. Rep.* **12**(1), 1. <https://doi.org/10.1038/s41598-022-14521-2> (2022).
20. Zhu, J. *et al.* Sustainable off-grid residential heating and desalination: Integration of biomass boiler and solar energy with environmental impact analysis. *J. Build. Eng.* **87**, 109035. <https://doi.org/10.1016/j.jobbe.2024.109035> (2024).
21. Liang, J. *et al.* An energy-oriented torque-vector control framework for distributed drive electric vehicles. *IEEE Trans. Transport. Electr.* **9**(3), 4014–4031. <https://doi.org/10.1109/TTE.2022.3231933> (2023).
22. Alturki, F. A. & Awwad, E. M. Sizing and cost minimization of standalone hybrid wt/pv/biomass/pump-hydro storage-based energy systems. *Energies* **14**(2), 489 (2021).
23. Belmilil, H., Haddadi, M., Bacha, S., Almi, M. F. & Bendib, B. Sizing stand-alone photovoltaic–wind hybrid system: Techno-economic analysis and optimization. *Renew. Sustain. Energy Rev.* **30**, 821–832 (2014).
24. Diaf, S., Belhamel, M., Haddadi, M. & Louche, A. Technical and economic assessment of hybrid photovoltaic/wind system with battery storage in Corsica island. *Energy Policy* **36**(2), 743–754. <https://doi.org/10.1016/j.enpol.2007.10.028> (2008).
25. Alshammari, S. & Fathy, A. Optimum size of hybrid renewable energy system to supply the electrical loads of the northeastern sector in the Kingdom of Saudi Arabia. *Sustainability* **14**(20), 13274 (2022).
26. Yeshalem, M. T. & Khan, B. Design of an off-grid hybrid PV/wind power system for remote mobile base station: A case study. *Aims Energy* **5**(1), 96–112 (2017).
27. Geleta, D. K., & Manshahia, M. S. Optimal sizing of hybrid wind and solar renewable energy system: A case study of Ethiopia. In *Research Advancements in Smart Technology, Optimization, and Renewable Energy, IGI Global*, pp. 110–148 (2021).
28. Xu, X. *et al.* Optimized sizing of a standalone PV-wind-hydro power station with pumped-storage installation hybrid energy system. *Renew. Energy* **147**, 1418–1431. <https://doi.org/10.1016/j.renene.2019.09.099> (2020).
29. Sultan, H. M., Diab, A. A. Z., Oleg, N. K. & Irina, S. Z. Design and evaluation of PV-wind hybrid system with hydroelectric pumped storage on the National Power System of Egypt. *Global Energy Interconnect.* **1**(3), 301–311 (2018).
30. Kusakana, K. Feasibility analysis of river off-grid hydrokinetic systems with pumped hydro storage in rural applications. *Energy Convers. Manag.* **96**, 352–362 (2015).
31. Das, P., Das, B. K., Mustafi, N. N. & Sakir, M. T. A review on pump-hydro storage for renewable and hybrid energy systems applications. *Energy Storage* **3**(4), e223 (2021).
32. “Renewable Power Generation Costs in 2021,” /publications/2022/Jul/Renewable-Power-Generation-Costs-in-2021. Accessed: Oct. 04, 2022. [Online]. Available: <https://irena.org/publications/2022/Jul/Renewable-Power-Generation-Costs-in-2021>.
33. Zakeri, B. & Syri, S. Electrical energy storage systems: A comparative life cycle cost analysis. *Renew. Sustain. Energy Rev.* **42**, 569–596 (2015).
34. “GW 2S_smart wind turbine | GOLDWIND wind turbine manufacturer.” Accessed: Oct. 02, 2022. [Online]. Available: <https://www.goldwind.com/en/windpower/product-gw2s/>.
35. S. S. T. AG, “SMA America Confirms 25-year Design Life for Sunny Highpower PEAK3 Inverters.” Accessed: Sep. 14, 2022. [Online]. Available: <https://www.sma-america.com/newsroom/current-news/news-details/news/4958-sma-america-confirms-25-year-design-life-for-sunny-highpower-peak3-inverters.html>.
36. Diab, A. A. Z., Sultan, H. M. & Kuznetsov, O. N. Optimal sizing of hybrid solar/wind/hydroelectric pumped storage energy system in Egypt based on different meta-heuristic techniques. *Environ. Sci. Pollut. Res.* **27**(26), 32318–32340 (2020).
37. Samy, M. M., Mosaad, M. I. & Barakat, S. Optimal economic study of hybrid PV-wind-fuel cell system integrated to unreliable electric utility using hybrid search optimization technique. *Int. J. Hydrogen Energy* **46**(20), 11217–11231. <https://doi.org/10.1016/j.ijhydene.2020.07.258> (2021).
38. Shirkhani, M. *et al.* A review on microgrid decentralized energy/voltage control structures and methods. *Energy Rep.* **10**, 368–380. <https://doi.org/10.1016/j.egyr.2023.06.022> (2023).

39. Heidari, A., Imani, D. M., Khalilzadeh, M. & Sarbazvatan, M. Green two-echelon closed and open location-routing problem: Application of NSGA-II and MOGWO metaheuristic approaches. *Environ. Dev. Sustain.* **25**(9), 9163–9199. <https://doi.org/10.1007/s10668-022-02429-w> (2023).
40. Zheng, S., Hai, Q., Zhou, X. & Stanford, R. J. A novel multi-generation system for sustainable power, heating, cooling, freshwater, and methane production: Thermodynamic, economic, and environmental analysis. *Energy* **290**, 130084. <https://doi.org/10.1016/j.energy.2023.130084> (2024).
41. Agajie, T. F. *et al.* Optimal design and mathematical modeling of hybrid solar PV–Biogas generator with energy storage power generation system in multiobjective function cases. *Sustainability* **15**(10), 10. <https://doi.org/10.3390/su15108264> (2023).
42. Zhang, J., Chen, Y., Gao, Y., Wang, Z. & Peng, G. Cascade ADRC speed control base on FCS-MPC for permanent magnet synchronous motor. *J. Circ. Syst. Comput.* **30**(11), 2150202. <https://doi.org/10.1142/S0218126621502029> (2021).
43. Yang, C. *et al.* Optimized integration of solar energy and liquefied natural gas regasification for sustainable urban development: Dynamic modeling, data-driven optimization, and case study. *J. Clean. Prod.* <https://doi.org/10.1016/j.jclepro.2024.141405> (2024).
44. Zhang, J., Zhu, D., Jian, W., Hu, W. & Peng, G. Fractional order complementary non-singular terminal sliding mode control of PMSM based on neural network. *Int. J. Autom. Technol.* <https://doi.org/10.1007/s12239-024-00015-9> (2024).
45. Li, X., Wang, Z., Yang, C. & Bozkurt, A. An advanced framework for net electricity consumption prediction: Incorporating novel machine learning models and optimization algorithms. *Energy* **296**, 131259. <https://doi.org/10.1016/j.energy.2024.131259> (2024).
46. Zhou, S., Zhou, G., Liu, X. & Zhao, H. Dynamic freewheeling control for SIDO buck converter with fast transient performance, minimized cross-regulation, and high efficiency. *IEEE Trans. Ind. Electron.* **70**(2), 1467–1477. <https://doi.org/10.1109/TIE.2022.3156169> (2023).
47. Luo, J., Zhuo, W., Liu, S. & Xu, B. The optimization of carbon emission prediction in low carbon energy economy under big data. *IEEE Access* **12**, 14690–14702. <https://doi.org/10.1109/ACCESS.2024.3351468> (2024).
48. Tharwat, A., & Ahmed, M. M. MOGOA algorithm for constrained and unconstrained multiobjective optimization problems. Accessed: Feb. 12, 2024. [Online]. Available: https://www.academia.edu/36758267/MOGO_algorithm_for_constrained_and_unconstrained_multi_objective_optimization_problems.
49. Huy, T. H. B. *et al.* Performance improvement of multiobjective optimal power flow-based renewable energy sources using intelligent algorithm. *IEEE Access* **10**, 48379–48404 (2022).
50. Gao, J., Zhang, Y., Li, X., Zhou, X. & Kilburn, J. Thermodynamic and thermoeconomic analysis and optimization of a renewable-based hybrid system for power, hydrogen, and freshwater production. *Energy* **295**, 131002. <https://doi.org/10.1016/j.energy.2024.131002> (2024).
51. Ma, Z. *et al.* A review of energy supply for biomachine hybrid robots. *Cyborg. Bionic Syst.* **4**, 53. <https://doi.org/10.34133/cbsystems.0053> (2023).
52. Yang, Y. *et al.* Whether rural rooftop photovoltaics can effectively fight the power consumption conflicts at the regional scale—A case study of Jiangsu Province. *Energy Build.* **306**, 113921. <https://doi.org/10.1016/j.enbuild.2024.113921> (2024).
53. Fan, J. & Zhou, X. Optimization of a hybrid solar/wind/storage system with bio-generator for a household by emerging metaheuristic optimization algorithm. *J. Energy Storage* **73**, 108967. <https://doi.org/10.1016/j.est.2023.108967> (2023).
54. Megapctche, C. A. M. *et al.* Demand response-fuzzy inference system controller in the multiobjective optimization design of a photovoltaic/wind turbine/battery/supercapacitor and diesel system: Case of healthcare facility. *Energy Convers. Manag.* **291**, 117245 (2023).
55. Bai, X., He, Y. & Xu, M. Low-thrust reconfiguration strategy and optimization for formation flying using Jordan normal form. *IEEE Trans. Aerosp. Electron. Syst.* **57**(5), 3279–3295. <https://doi.org/10.1109/TAES.2021.3074204> (2021).
56. Li, P., Hu, J., Qiu, L., Zhao, Y. & Ghosh, B. K. A distributed economic dispatch strategy for power-water networks. *IEEE Trans. Control Netw. Syst.* **9**(1), 356–366. <https://doi.org/10.1109/TCNS.2021.3104103> (2022).
57. Rehman, S. *et al.* Optimal design and model predictive control of standalone HRES: A real case study for residential demand side management. *IEEE Access* **8**, 29767–29814. <https://doi.org/10.1109/ACCESS.2020.2972302> (2020).
58. Zhang, X. *et al.* Voltage and frequency stabilization control strategy of virtual synchronous generator based on small signal model. *Energy Rep.* **9**, 583–590. <https://doi.org/10.1016/j.egyr.2023.03.071> (2023).
59. “Status - SoDa.” Accessed: Jul. 11, 2023. [Online]. Available: <https://www.soda-pro.com/en/web/guest/research-projects/spectral-radiation/photosynthetically-active-radiation>.
60. Liang, J. *et al.* A direct yaw moment control framework through robust T-S fuzzy approach considering vehicle stability margin. *IEEE/ASME Trans. Mechatron.* **29**(1), 166–178. <https://doi.org/10.1109/TMECH.2023.3274689> (2024).
61. Peng, T., Zeng, H., Wang, W., Zhang, X. & Liu, X. General and less conservative criteria on stability and stabilization of T-S Fuzzy systems with time-varying delay. *IEEE Trans. Fuzzy Syst.* **31**(5), 1531–1541. <https://doi.org/10.1109/TFUZZ.2022.3204899> (2023).
62. Li, S., Zhao, X., Liang, W., Hossain, M. T. & Zhang, Z. A fast and accurate calculation method of line breaking power flow based on Taylor expansion. *Front. Energy Res.* **10**, 1. <https://doi.org/10.3389/ferng.2022.943946> (2022).
63. Hou, M., Zhao, Y. & Ge, X. Optimal scheduling of the plug-in electric vehicles aggregator energy and regulation services based on grid to vehicle. *Int. Trans. Electr. Energy Syst.* **27**(6), e2364. <https://doi.org/10.1002/etep.2364> (2017).
64. Lyu, W. *et al.* Impact of battery electric vehicle usage on air quality in three Chinese first-tier cities. *Sci. Rep.* **14**(1), 21. <https://doi.org/10.1038/s41598-023-50745-6> (2024).
65. Mfetoum, I. M. *et al.* A multilayer perceptron neural network approach for optimizing solar irradiance forecasting in Central Africa with meteorological insights. *Sci. Rep.* **14**, 3572. <https://doi.org/10.1038/s41598-024-54181-y> (2024).
66. Mohapatra, B. *et al.* Optimizing grid-connected PV systems with novel super-twisting sliding mode controllers for real-time power management. *Sci. Rep.* **14**, 4646. <https://doi.org/10.1038/s41598-024-55380-3> (2024).
67. Deghfel, N. *et al.* A new intelligently optimized model reference adaptive controller using GA and WOA-based MPPT techniques for photovoltaic systems. *Sci. Rep.* **14**, 6827. <https://doi.org/10.1038/s41598-024-57610-0> (2024).

Author contributions

Elsabet Ferede Agajie, Takele Ferede Agajie, Isaac Amoussou: conceptualization, methodology, software, visualization, investigation, writing—original draft preparation. Armand Fopah-Lele, Wirnkar Basil Nsanyuy, Baseem Khan: data curation, validation, supervision, resources, writing—review and editing. Mohit Bajaj, Ievgen Zaitsev, Emmanuel Tanyi: project administration, supervision, resources, writing—review and editing.

Competing interests

The authors declare no competing interests.

Additional information

Correspondence and requests for materials should be addressed to T.F.A., M.B. or I.Z.

Reprints and permissions information is available at www.nature.com/reprints.

Publisher's note Springer Nature remains neutral with regard to jurisdictional claims in published maps and institutional affiliations.



Open Access This article is licensed under a Creative Commons Attribution 4.0 International License, which permits use, sharing, adaptation, distribution and reproduction in any medium or format, as long as you give appropriate credit to the original author(s) and the source, provide a link to the Creative Commons licence, and indicate if changes were made. The images or other third party material in this article are included in the article's Creative Commons licence, unless indicated otherwise in a credit line to the material. If material is not included in the article's Creative Commons licence and your intended use is not permitted by statutory regulation or exceeds the permitted use, you will need to obtain permission directly from the copyright holder. To view a copy of this licence, visit <http://creativecommons.org/licenses/by/4.0/>.

© The Author(s) 2024