



Since January 2020 Elsevier has created a COVID-19 resource centre with free information in English and Mandarin on the novel coronavirus COVID-19. The COVID-19 resource centre is hosted on Elsevier Connect, the company's public news and information website.

Elsevier hereby grants permission to make all its COVID-19-related research that is available on the COVID-19 resource centre - including this research content - immediately available in PubMed Central and other publicly funded repositories, such as the WHO COVID database with rights for unrestricted research re-use and analyses in any form or by any means with acknowledgement of the original source. These permissions are granted for free by Elsevier for as long as the COVID-19 resource centre remains active.

varies according to the size of the operatory and can easily be calculated by dentists using the following simple formula: $\text{airflow} = \text{ACH} \times \text{volume}/60$, where airflow is the mechanically exhausted airflow rate in cu ft/min and volume is the room air volume ($\text{length} \times \text{width} \times \text{height}$). The maintenance of negative pressure ensures prevention of the spread of COVID-19 from the operatory to other areas, and it is easily achieved by maintaining exhausted air 10% to 15% more than the supplied air. AAD means that clean air is first passed over the dentist/assistant and then to the patient to reduce the staff's exposure to COVID-19. This is accomplished by introducing the air from ceiling registers and is exhausted through registers located at least 6 inches above the floor (Fig. 1). A high-efficiency particulate air machine can be incorporated in the dental setup to clean contaminated air and to induce negative pressure in the room.

The article mentions the Center for Disease Control and Prevention's guidelines of donning recommending the use of goggles or a face shield. However, face shields should not be used as the primary face/eye protector because of the lack of a peripheral facial seal and the decreased efficacy for small aerosolized particles. Whenever possible, goggles should be used as a primary eye protector along with a face shield to protect the rest of the face.

We hope that the aforementioned points add clinically relevant information to the review article that will benefit the readers working in clinical dental care.

Ganesh R. Jadhav, MDS

Department of Dentistry, All India Institute of Medical Sciences (AIIMS), Nagpur, India
e-mail: drganesh2009.aiims@gmail.com

Priya Mittal, MDS

Pune, India

Copyright © 2020 Published by Elsevier Inc. on behalf of American Association of Endodontists.

<https://doi.org/10.1016/j.joen.2020.05.026>

REFERENCES

1. Ather A, Patel P, Ruparel NB, et al. Coronavirus disease 19 (COVID-19): implications for clinical dental care. *J Endod* 2019;45:357–63.
2. Gandhi M, Yokoe DS, Havir DV. Asymptomatic transmission, the Achilles' heel of current strategies to control Covid-19. *N Engl J Med* 2020;382:2158–60.
3. To KK-W, Tsang OT-Y, Leung W-S, et al. Temporal profiles of viral load in posterior oropharyngeal saliva samples and serum antibody responses during infection by SARS-CoV-2: an observational cohort study. *Lancet Infect Dis* 2020;20:564–74.

4. Gattinoni L, Chiumello D, Caironi P, et al. COVID-19 pneumonia: different respiratory treatments for different phenotypes? *Intensive Care Med* 2020;46:1099–102.
5. World Health Organization. Pulse oximetry training manual. Available at: http://www.who.int/patientsafety/safesurgery/pulse_oximetry/tr_material/en/. Accessed May 7, 2020.

Reply to “Coronavirus Disease 19 (COVID-19): Implications for Clinical Dental Care”



To the Editor:

We would like to thank Drs Jadhav and Mittal for their letter to the editor in which they have put forward their concerns and suggestions regarding the manuscript titled “Coronavirus Disease 19 (COVID-19): Implications for Clinical Dental Care”¹. We appreciate their insight and would like to take the opportunity to comment on their suggestions.

We strongly agree with the concerns expressed by the authors regarding asymptomatic carriers of COVID-19 and the potential transmission to dental health care professionals. The authors raise an important point about the use of pulse oximetry to detect low blood oxygen saturation levels in asymptomatic carriers. However, it is noteworthy that pulse oximeter detects hypoxemia in contrast to “hypoxia” as mentioned by the authors. The term *hypoxia* denotes reduced tissue-level oxygenation and is not synonymous with hypoxemia (reduced blood oxygen saturation)². In agreement with the authors, oxygen saturation measurements are a vital screening tool to identify potential asymptomatic patients and should be incorporated into routine dental clinical practice. Notably, the potential importance of silent hypoxemia in COVID-19 patients has become evident only more recently³. Thus, at the time of manuscript submission, we refrained from making recommendations without proper scientific citable evidence. As more is known about COVID-19, we believe that readers should maintain a pragmatic approach incorporating new peer-reviewed evidence in their practice.

We appreciate the authors for elaborating on the outline and basic design considerations for negative-pressure rooms/airborne infection isolation rooms for dental practices. Given the surge in airborne infections over the past few decades and the fact that only 2%–4% of rooms are equipped with negative pressure in approximately half of urban hospitals⁴, efforts

could be directed toward creating more negative-pressure rooms for health care providers. As mentioned by the authors, negative-pressure rooms should be built following stringent guidelines. In addition, these isolation rooms require continuous monitoring to measure pressure differential and proper training of staff to operate and check these rooms for “leaks.” Failure to do so has led to nosocomial spread of infection in the past⁵. As an alternative, knowledge of health care centers with provision for a negative-pressure room would help dentists to provide emergent dental care to patients with confirmed or suspected COVID-19 infection, as mentioned in our article¹.

Regarding the Centers for Disease Control and Prevention guidelines on sequence for putting on personal protective equipment, it is important to note that these guidelines have been issued keeping in mind the shortage of personal protective equipment during this pandemic⁶. However, it is in the best interest of the health care providers to use both goggles or loupes and a face shield for added protection if there is an adequate supply.

Amber Ather, BDS, DDS

Biraj Patel, BDS

Nikita B. Ruparel, MS, DDS, PhD

Anibal Diogenes, DDS, MS, PhD

Kenneth M. Hargreaves, DDS, PhD

Department of Endodontics, University of Texas Health Science Center at San Antonio, San Antonio, Texas

Copyright © 2020 Published by Elsevier Inc. on behalf of American Association of Endodontists.

<https://doi.org/10.1016/j.joen.2020.08.005>

REFERENCES

1. Ather A, Patel B, Ruparel NB, et al. Coronavirus disease 19 (COVID-19): implications for clinical dental care. *J Endod* 2020;46:584–95.
2. Hypoxemia vs. hypoxia. *N Engl J Med* 1966;274:908–9.
3. Ottestad W, Seim M, Mæhlen JO. COVID-19 with silent hypoxemia. *Covid-19 med stille hypoksemi. Tidsskr Nor Laegeforen* 2020;140.
4. Miller SL, Clements N, Elliott SA, et al. Implementing a negative-pressure isolation ward for a surge in airborne infectious patients. *Am J Infect Control* 2017;45:652–9.
5. Schwartzman K, Loo V, Pasztor J, Menzies D. Tuberculosis infection among health care workers in Montreal. *Am J Respir Crit Care Med* 1996;154:1006–12.
6. COVID-19: Strategies for Optimizing the Supply of PPE | CDC. Available at: <https://www.cdc.gov/coronavirus/2019-ncov/hcp/ppe-strategy/index.html>. Accessed August 19, 2020.