


# UVGI CALCULATION

## Project Information



Minimal Intensity: 45  $\mu\text{W}/\text{cm}^2$   
Maximal Intensity: 28'396  $\mu\text{W}/\text{cm}^2$   
Average Intensity: 1'612  $\mu\text{W}/\text{cm}^2$

Air Volume: 1800.0  $\text{m}^3/\text{h}$   
Time of Exposure: 1.13 s  
Air Temperature: 20.0  $^\circ\text{C}$   
Relative Humidity [RH]: 66 %