

Supplemental Information

India's potential for integrating solar and on- and offshore wind power into its energy system

Tianguang Lu, Peter Sherman, Xinyu Chen, Shi Chen, Xi Lu, Michael
McElroy

Supplementary Table 1 Specifications for the on- and offshore turbines used here.

Specifications	GE 2.5 MW	Vestas 8.0 MW
Rated power	2,500.0 kW	8,000.0 kW
Cut-in wind speed	3.0 m/s	4.0 m/s
Rated wind speed	13.0 m/s	13.0 m/s
Cut-out wind speed	25.0 m/s	25.0 m/s
Diameter	100.0 m	164.0 m
Swept area	7,853.9 m ²	21,164.1 m ²
Number of blades	3	3

Supplementary Table 2. Per unit costs [\$/kW] associated with interregional transmission of power.

Interregional corridor	Cost [\$/kW]
East-North	65.21
East-Northeast	48.19
East-South	61.72
East-West	2.07
North-West	63.85
North-Northeast	48.19
South-West	107.46

Supplementary Table 3. Costs for mechanical and chemical storage associated with the three scenarios. E represents the energy-specific cost in \$/kWh and P represents the power-specific cost in \$/kW.

	Low cost		Medium cost		High cost	
	E	P	E	P	E	P
Mechanical Storage	60	1200	70	1400	80	1600
Chemical Storage	120	240	160	320	200	400

Supplementary Table 4. Properties of small (10-300 MW), medium (300-600 MW) and large (600-1000 MW) thermal units (coal and natural gas). Data from the IEA [1].


	Coal			Gas		
	Small	Medium	Large	Small	Medium	Large
Max. output [%]	100	100	100	100	100	100
Min. output [%]	50	50	50	25	40	40
Capital cost [\$/kW]	621	585	515	524	488	418
O&M [% of Capital cost]	2.1	2.0	1.9	2.6	2.5	2.4
Start-up cost [\$/MW]	147	147	147	88	88	88
Min. up time [hr.]	8	8	24	1	4	6
Min. down time [hr.]	4	8	48	1	2	12
Ramping limit [%/hr.]	35	35	35	100	50	50

Supplementary Table 5. Inputs for the cost-optimization model. Columns indicate the different scenarios investigated in the cost-optimization model, specifically (1) the standard scenario (standard), (2) the standard scenario with low cost storage (low cost storage), (3) the standard scenario with no storage (no storage), (4) the standard scenario with high cost renewables (high cost renewables) and (5) the standard scenario with no storage and high price gas (high gas price).


	Standard	Low cost storage	No storage	High cost renewables	High gas price
PV [\$/kW]	550	550	550	1650	550
Onshore wind [\$/kW]	980	980	980	1950	980
Offshore wind [\$/kW]	1300	1300	1300	2300	1300
Coal fuel [\$/MMBTU]	3.6	3.6	3.6	3.6	3.6
Gas fuel [\$/MMBTU]	7.65	7.65	7.65	7.65	11
Coal and gas options	Table S3	Table S3	Table S3	Table S3	Table S3
Transmission	Table S1	Table S1	Table S1	Table S1	Table S1
Storage	Medium cost, Table S2	Low cost, Table S2	--	Medium cost, Table S2	--

Supplementary Table 6. Parameter settings for the solar filter.


	Parameters	Setting
Suitability Factor of Land use (%)	All forest	0
	Closed shrublands, woody savannas	5
	Grasslands, open shrublands, savannas	20
	Barren or sparsely vegetated	20
	Croplands, cropland/natural vegetation mosaic	0
	Urban and built-up	5
	Water bodies, permanent wetlands, snow and ice	0
Slope (%)		< 5
Solar Radiation (kWh/(m²·a))		> 1400




Supplementary Figure 1 Land type classifications. Classification of different land types as determined by the MODIS (Moderate Resolution Imaging Spectroradiometer) satellite MCD12C1 dataset [2]. The percentage of India's overall land mass classified as a specific land type is denoted in parenthesis in the legend. This figure was constructed in MATLAB version 2017b and edited in Adobe InDesign 2020.




Supplementary Figure 2 Wind power curves. Wind power curves for the two wind turbines used in this study.




Supplementary Figure 3 Geographical distribution and capacities for coal, gas and nuclear power stations. Coal plants are indicated in dark red, gas in blue and nuclear in light brown. Coal data are derived from [3] and gas and nuclear data are derived from [4]. This figure was constructed in MATLAB version 2017b and edited in Adobe InDesign 2020.




Supplementary Figure 4 Hourly power demand in 2016. Hourly data for five regions for a typical day in each month derived from POSOCO [5].




Supplementary Figure 5 National generation mix. National generation mix of capacities (GW) for 80% renewables as a function of different scenarios summarized in Supplementary Table 5.




Supplementary Figure 6 National system costs. System costs for 80% renewables as a function of different scenarios summarized in Supplementary Table 5.



Supplementary Figure 7 CO₂ reduction costs. Costs for CO₂ reductions [in \$/ton] for 80% renewables as a function of different scenarios summarized in Supplementary Table 5.



Supplementary Figure 8 Seasonal hourly power balance. Hourly power balances defined for seasonally representative weeks on the basis of the 40% renewables standard model simulation: February 1-7 (a), May 1-7 (b), August 1-7 (c) and November 1-7 (d).



Supplementary Figure 9 Seasonal hourly power balance. Hourly power balances defined for seasonally representative weeks on the basis of the 60% renewables standard model simulation: February 1-7 (a), May 1-7 (b), August 1-7 (c) and November 1-7 (d).

Supplementary Methods: Mathematical formulation of the proposed optimization model

The decision variables in the operational component are constrained by those in the capacity expansion component mainly in three ways. First, the hourly power generation and hourly online capacities are constrained by the total capacity available for a specific thermal technology (coal or gas):

$$0 \leq p_{t,k}^i \leq \bar{p}_{t,k}^i \leq \bar{I}_k^i = I_k^i + I_{i,k}^0 \quad (1)$$

where $p_{t,k}^i$ and $\bar{p}_{t,k}^i$ define the power generation and online capacity for i^{th} category of thermal units in region k at time t . \bar{I}_k^i , I_k^i and $I_{i,k}^0$ denote the total capacity, the installed capacity and the newly expanded capacity (between 2019 and 2040 in this study) for i^{th} category of thermal units in region k .

Second, wind and solar power are constrained by the total capacity, associated with the hourly capacity factor calculated based on physical potential:

$$0 \leq p_{t,k}^w \leq \alpha_{t,k} \cdot \bar{I}_k^w = \alpha_{t,k} \cdot (I_k^w + I_{w,k}^0) \quad (2)$$

$$0 \leq p_{t,k}^s \leq \beta_{t,k} \cdot \bar{I}_k^s = \beta_{t,k} \cdot (I_k^s + I_{s,k}^0) \quad (3)$$

where $p_{t,k}^w$ and $p_{t,k}^s$ represent the power generations for wind and solar in region k at time t . Hourly capacity factors for wind and solar are denoted by $\alpha_{t,k}$ and $\beta_{t,k}$. \bar{I}_k^x , I_k^x and $I_{x,k}^0$ denote the total capacity, the installed capacity and the newly expanded capacity for wind ($x=w$) and solar ($x=s$) in region k .

Third, the hourly power exchange between two regions is constrained by the inter-regional transmission capacity:

$$-L_{j,k} - L_{j,k}^0 = \underline{L}_{j,k} \leq p_{j,k}^i \leq \bar{L}_{j,k} = L_{j,k} + L_{j,k}^0 \quad (4)$$

where $p_{j,k}^i$ represents the transmitted power between regions j and k at hour t . $\bar{L}_{j,k}$ and $\underline{L}_{j,k}$ denote the maximum and minimum transmission capacity. $L_{j,k}$ and $L_{j,k}^0$ denote the installed capacity and the newly expanded capacity for inter-regional transmission corridor $j-k$.

The objective of the ESCEM is to minimize the overall system costs, which include two parts: annual operational costs C_{op} with hourly resolution (fuel costs C_{fuel} , start-up costs C_{st} and operational costs for storage system C_{es} , hydro power C_h and nuclear power C_{nu}), and capacity costs C_{cap} (amortized investment costs C_{inv} , fixed O&M costs C_{om} and costs for inter-regional network expansion C_{net}):

$$\min C_{op} + C_{cap} = (C_{fuel} + C_{st} + C_{es} + C_h + C_{nu}) + (C_{inv} + C_{om} + C_{net}) \quad (5)$$

such that:

$$\begin{cases} C_{inv} = \sum_{k=1}^{N_a} \left(\sum_{i=1}^{M_k} a_k^i \cdot I_k^i + a_k^w \cdot I_k^w + a_k^s \cdot I_k^s + \sum_{z=1}^{N_{es}} (a_k^{p,z} \cdot \bar{I}_k^{p,z} + a_k^{e,z} \cdot \bar{I}_k^{e,z}) \right) \\ C_{om} = \sum_{k=1}^{N_a} \left(\sum_{i=1}^{M_k} f_k^i \cdot \bar{I}_k^i + f_k^w \cdot \bar{I}_k^w + f_k^s \cdot \bar{I}_k^s \right) \\ C_{net} = \sum_{(j,k) \in \Psi} a_{j,k}^l \cdot L_{j,k}^0 \end{cases} \quad (6)$$

$$\begin{cases} C_{fuel} = \sum_{k=1}^{N_a} \sum_{i=1}^{M_k} \sum_{t=1}^T c_k^i \cdot p_{t,k}^i \\ C_{st} = \sum_{k=1}^{N_a} \sum_{i=1}^{M_k} \sum_{t=1}^T SD_k^i \cdot s_{t,k}^i \\ C_{es} = \sum_{k=1}^{N_a} \sum_{z=1}^{N_{es}} \sum_{t=1}^T c_k^{es,z} \cdot (p_{t,k}^{dis,z} + p_{t,k}^{ch,z}) \\ C_h = \sum_{k=1}^{N_a} \sum_{t=1}^T c_k^h \cdot p_{t,k}^h \\ C_{nu} = \sum_{k=1}^{N_a} c_k^{nu} \end{cases} \quad (7)$$

where N_a and M_k denote the numbers of regions and categories of thermal units in region k . a_k^i and f_k^i are the amortized investment cost and fixed O&M cost for thermal units. a_k^x and f_k^x are the amortized investment costs and fixed O&M costs for wind ($x=w$) and solar ($x=s$). $\bar{I}_k^{p,z}$ and $\bar{I}_k^{e,z}$ denote the power and energy capacities for the newly installed storage systems; $a_k^{p,z}$ and $a_k^{e,z}$ represent the corresponding power-specific and energy-specific amortized investment cost for z^{th} category of storages in region k . $a_{j,k}^l$ is the investment cost for the newly expanded capacity for inter-regional transmission corridor. Ψ denotes the set of inter-regional transmission corridors. The operational costs for thermal units,

energy storage and hydro power are c_k^i , $c_k^{es,z}$ and c_k^h . The annual fixed operational cost for nuclear power is denoted as c_k^{nu} . SD_k^j represents the start-up cost for thermal units.

Constraints including unit commitment, operations for energy storages, the system power balances and reserves, renewable penetration and intra-regional power flow are considered in the model.

Constraints relating to operations for energy storage are considered based on different regional distributions and storage types. The charging ($p_{t,k}^{ch,z}$) and discharging ($p_{t,k}^{dis,z}$) power for the z^{th} category of energy storage in region k is constrained by the non-negative power capacity of newly installed storage:

$$0 \leq p_{t,k}^{dis,z} \leq \bar{I}_k^{p,z} \quad (8)$$

$$0 \leq p_{t,k}^{ch,z} \leq \bar{I}_k^{p,z} \quad (9)$$

The energy flow from a storage system is restricted by the following energy balance:

$$e_{t+1,k}^{es,z} = e_{t,k}^{es,z} + \gamma_{es}^{ch,z} \cdot p_{t,k}^{ch,z} - \frac{1}{\gamma_{es}^{dis,z}} \cdot p_{t,k}^{dis,z} - \gamma_{es}^{self,z} \cdot e_{t,k}^{es,z} \quad (10)$$

where $e_{t,k}^{es,z}$ denotes the energy state that satisfies $0 \leq e_{t,k}^{es,z} \leq \bar{I}_k^{e,z}$. The energy state in the last time interval is equal to that of the first time interval. ($\gamma_{es}^{ch,z}$, $\gamma_{es}^{dis,z}$) and $\gamma_{es}^{self,z}$ represent the energy efficiency and loss (self-discharge) rates.

To quantify the spinning reserve $r_{t,k}^{es,z}$ provided by storage systems, the following formulation is considered:

$$0 \leq p_{t,k}^{dis,z} + r_{t,k}^{es,z} \leq \bar{I}_k^{p,z} \quad (11)$$

$$0 \leq r_{t,k}^{es,z} \leq \bar{I}_k^{p,z} \quad (12)$$

$$0 \leq e_{t,k}^{es,z} - \frac{1}{\gamma_{es}^{dis,z}} \cdot (p_{t,k}^{dis,z} + r_{t,k}^{es,z}) - \gamma_{es}^{self,z} \cdot e_{t,k}^{es,z} \quad (13)$$

For chemical storage, the annual energy flow is restricted by the amortized watt-hours passing through the battery:

$$\sum_{t=1}^T (p_{t,k}^{dis,z} + p_{t,k}^{ch,z}) \leq \bar{I}_k^{e,z} \cdot H_{es}^z \quad (14)$$

where H_{es}^z is the annualized watt-hours throughput.

Constraints for the power balance and reserve are considered to meet requirements for the reliability of power grid operation. For every time interval, the power demand equals the sum of the power outputs from all categories of thermal units, hydropower and nuclear power plants, energy storage systems, plus the outputs from wind, solar and inter-regionally transmitted power:

$$\sum_{i=1}^{M_k} p_{t,k}^i + p_{t,k}^w + p_{t,k}^s + p_{t,k}^h + p_{t,k}^{nu} + \sum_{j \in \Psi_k} p_{j,k}^t + \sum_{z=1}^{N_{es}} (p_{t,k}^{dis,z} - p_{t,k}^{ch,z}) = D_{t,k} \quad (15)$$

where Ψ_k defines the set of regions connected to region k . $D_{t,k}$ denotes the power demand at time t for region k . $p_{t,k}^h$ and $p_{t,k}^{nu}$ represent the hydropower and nuclear power.

The forecasting errors in energy demand R^d and wind R^w and solar R^s output are considered in the following reserve constraint:

$$\begin{aligned} \sum_{i=1}^{M_k} \bar{\mu}_k^i \cdot \bar{p}_{t,k}^i + \alpha_{t,k} \cdot \bar{I}_k^w + \beta_{t,k} \cdot \bar{I}_k^s + \sum_{z=1}^{N_{es}} (p_{t,k}^{dis,z} + r_{t,k}^{es,z}) + \sum_{j \in \Psi_k} p_{j,k}^t \\ \geq (1 + R^d) \cdot D_{t,k} + R^w \cdot p_{t,k}^w + R^s \cdot p_{t,k}^s \end{aligned} \quad (16)$$

The constraints of downward reserve are not considered in the model because wind and solar can provide the downward reserve by curtailing their power output in real time during contingency, and thus the downward reserve is not binding in day-ahead scheduling. The minimum load (over generation) problem is captured mainly by the minimum power output and ramping constraints in this formulation.

To meet requirements for system reliability, the system invested capacity must be no less than the required capacity standard:

$$\sum_{i=1}^{M_k} \bar{I}_k^i + \lambda_k^w \cdot \bar{I}_k^w + \lambda_k^s \cdot \bar{I}_k^s \geq D_k^{\max} \quad (17)$$

where D_k^{\max} is the required capacity to satisfy reliability standards. λ_k^w and λ_k^s denote the capacity credits for wind and solar power in region k .

Constraints for renewable portfolio requirements are incorporated to set different levels of

renewable penetration for the energy system:

$$\sum_{k=1}^{N_a} \sum_{t=1}^T (p_{t,k}^w + p_{t,k}^s) \cdot \Delta t = \Gamma \cdot \sum_{k=1}^{N_a} D_{t,k} \quad (18)$$

where Γ ($0 \leq \Gamma \leq 80\%$ in this study) is the required renewable percentage for the overall renewable portfolio target.

To sum up, the above optimization model minimizes the overall costs for power grid operation and capacity investment under a given renewable penetration, as indicated in equations (5)-(7), constrained by equations (1)-(4) associated with investment and operational decisions, unit commitment, (8)-(14) for storage operation, (15)-(17) for system energy balance and reserves and (18) for the required percentage of renewables. The simulation for India's energy system projected in 2040 covers the timescale of 8760 hours and requires a total of approximately 5 million variables.

Supplementary Note: CO₂ Emissions from energy system

The total CO₂ emissions from India's energy system in 2040 are calculated based on the emission factors of CO₂ and the annual power generation of all thermal generators:

$$E^s = e^i \cdot \sum_{k=1}^{N_a} \sum_{i=1}^{M_k} \sum_{t=1}^T p_{t,k}^{i,s} \quad (19)$$

where E^s is the total CO₂ emissions under scenario s . Possible values of s range from 1-5, representing the corresponding scenarios in Supplementary Table 5. e^i denotes the emission factor for CO₂ from i^{th} category for thermal units. $p_{t,k}^{i,s}$ defines power generation for i^{th} category for thermal units in region k at time t under scenario s .

References

1. International Energy Agency. Global energy CO₂ status report—The latest trends in energy and emissions in 2018. (International Energy Agency, 2019).
2. NASA Land Processes Distributed Active Archive Center (LP DAAC). MCD12C1: Land Cover Type Yearly L3 Global 500 m SIN Grid.
https://lpdaac.usgs.gov/dataset_discovery/modis/modis_products_table/mcd12c1
(2012),
3. Central Electricity Authority, Ministry of Power. Coal based Thermal Units Retired Since Sept.'15 to March'18. (Government of India 2018).
4. Central Electricity Authority. Executive summary of Power Sector as on 30-09-2018. (Government of India 2016).
5. Power System Operation Corporation Ltd. Electricity demand pattern analysis. (Power System Operation Corporation Ltd., 2018)